

Water Quality Report

# Royston Improvement District



**Comox Valley**  
REGIONAL DISTRICT

comoxvalleyrd.ca



## TABLE of CONTENTS


<b>Map of Service Area</b> .....	<b>1</b>
<b>Introduction</b> .....	<b>2</b>
<b>Operations</b> .....	<b>2</b>
Goals.....	2
Water Quality Summary.....	4
Canadian Drinking Water Guidelines.....	6
<b>Planning</b> .....	<b>7</b>
Goals.....	7
Consumption .....	7
Maintenance .....	8
Financial .....	8
<b>2017 Accomplishments</b> .....	<b>9</b>
<b>2018 Objectives</b> .....	<b>9</b>
Appendix A: Parameter Details.....	10

*“The CVRD strives to provide high quality drinking water to the Royston Water Local Service Area, 2017 saw the completion of additional source water study work and continued water quality monitoring for the service. ”*

*-Mike Herschmiller, Manager of Water Services*



## Map of Service Area



## Introduction

The Comox Valley Regional District (CVRD) strives to provide high quality drinking water to the Royston Water Local Service Area, through responsible operation, monitoring, and management of the water system. The CVRD is regulated by Island Health as part of the Ministry of Health for its activities as a potable water supplier. Under the *Drinking Water Protection Act* (DWP Act), the CVRD is now required to report annually on water quality for the Royston Drinking Water System. This report covers the period from January 1 to December 31, 2017 and includes information on water quality, consumption, maintenance and capital projects.



Figure No.1: Royston Chlorination Station.

The Royston Water Service provides domestic water to approximately 2,100 residents located in the CVRD Electoral Area 'A'. The service is owned and operated by the CVRD and is funded through a combination of frontage tax and user rates.

Treated water is supplied for the service via a transmission main from the Village of Cumberland. Once water enters the Royston system it is given a secondary dose of chlorine prior to distribution. The system consists of two reservoirs and five pressure reducing valve chambers.

## Operations

### Goals

To provide high quality drinking water to all customers through efficient and effective disinfection and distribution operations.

### Water Quality Summary

Parameter <sup>1</sup>	2016	2017	Target
<b>Water Disinfection</b>			
Chlorine Residual (mg/L)- Royston Reservoir	1.08	1.17	<2.0
Trihalomethanes (mg/L)	0.034	0.043	<0.1
<b>Residual Disinfection</b>			
Chlorine residual- distribution system (mg/L)	0.84	0.79	>0.20
Total Coliforms (positive samples)	0	0	0
E.Coli (positive samples)	0	0	0
<b>Canadian Drinking Water Quality Guidelines</b>			
Distribution Turbidity (average NTU)	0.56	0.55	<1.0
Distribution Water Temperature (Celsius)	10.7	12.5	15
Distribution Water pH	7.01	7.46	6.5-8.5

<sup>1</sup>More information for each parameter is available later on in the report.

The Ministry of Health regulates municipal drinking water quality through the DWP Act and the *Drinking Water Protection Regulation* (the Regulation). The DWP Act and Regulation are administered by regional health authorities, and for the CVRD, the administering authority is Island Health. Both the DWP Act and Regulation set out certain requirements for drinking water operators and suppliers to ensure the provision of safe drinking water to their customers.

In the Royston system, treated water is received via a transmission main from the Village of Cumberland and is given a secondary dose of chlorine prior to distribution. After the water is re-chlorinated it proceeds into the distribution system, either directly to the Kentwood Road area or via a series of reservoirs and pressure reducing valves. The CVRD takes weekly water quality samples at five fixed locations within the distribution system, to ensure that water is meeting provincial objectives. Testing for distribution by-products is taken from the Royston reservoir and a water chemistry report is completed quarterly. A summary and description of water quality results are described below.

### Disinfection

All water supply systems governed by Island Health that are using surface water are required to adhere to provincial 4-3-2-1-0 surface water treatment objectives to ensure that the water treatment process is effectively killing disease causing viruses, bacteria and parasites.


Currently the source water for the Royston system is already treated by the Village of Cumberland and is compliant with provincial regulations. However for water quality assurance purposes, prior to the water entering the Royston system, water is given a secondary dose of chlorine.

By dosing the water with chlorine, a free chlorine residual is established throughout the distribution network to help prevent bacteriological regrowth and cross contamination during storage. The free chlorine residual is an indicator of the effectiveness of disinfection within the distribution system. The CVRD strives to maintain a free chlorine residual above 0.2mg/L at the end of the system. The CVRD regularly monitors the chlorine residual throughout the distribution network at five fixed locations. The average results are shown in Figure No.3 below.



**Figure No.2: Chlorine Injection at the Royston Chlorination Station.**





**Figure No.3: Average Chlorine Residual at the Royston Sampling Locations**

A by-product of chlorination can be Trihalomethanes (THM). There are four types of THM's that contribute to the total THM's. Chloroform is the most common THM and is formed when natural organic matter reacts with chlorine and/or bromine in disinfected water. The guidelines require that the total THM's for drinking water must be less than 0.1mg/L, THM's are sampled quarterly. Table No.1 below shows the average THM's at the Royston reservoir. No THM results were higher than the guidelines.

**Table No.1: Total THM Concentration at the Royston Reservoir**

Trihalomethanes	Royston Reservoir
Chloroform	0.042
Bromodichloromethane	<0.001
Dibromochloromethane	<0.001
Bromoform	<0.001
<b>Average Total THMs (mg/L)</b>	<b>0.043</b>

## Bacteria

E.Coli and total coliform bacteria are microorganisms that if present in water samples indicate possible contamination with sewage or animal wastes. Chlorination helps to remove harmful pathogens within the water supply network. Table No.2 below shows that within the Royston Water Distribution System for 2017, there were zero positive results found for E.Coli and total coliforms.

**Table No.2: Bacteriological Standards and Sampling Results**

Results	E.Coli		Total Coliform Bacteria	
	Exceedances <sup>1</sup>	# of Samples	Exceedances <sup>2</sup>	# of Samples
January	0	5	0	5
February	0	4	0	4
March	0	3	0	3
April	0	4	0	4
May	0	4	0	4
June	0	4	0	4
July	0	5	0	5
August	0	4	0	4
September	0	4	0	4
October	0	4	0	4
November	0	4	0	4
December	0	3	0	3
<b>Totals</b>	<b>0 exceedances per 48 samples</b>		<b>0 exceedances per 48 samples</b>	

## Canadian Drinking Water Guidelines

Health Canada develops the *Canadian Drinking Water Guidelines*. These are guidelines for limits on microbial, chemical, physical and radiological substances in drinking water. In the guidelines, health-based limits are identified for each substance as maximum allowable concentrations. The guidelines also assign aesthetic objectives to substances that do not cause risk to human health, but will influence consumer acceptance of the water based on factors such as taste, odour and colour. Water is sampled quarterly, Table No.3 shows the Royston reservoir drinking water averages concentration for multiple parameters compared to the guideline concentrations. In 2017, the system was below all maximum allowable concentrations and aesthetic objectives as illustrated in Table No.3.

**Table No.3: Chemical and Physical Parameters at Royston Reservoir Compared to Guideline Concentrations**

Parameter	Royston Reservoir (mg/L)	Guideline Concentration (mg/L)
Aluminum	0.0223	≤0.1
Arsenic	<0.00002	≤0.01
Barium	<0.001	≤1.0
Boron	0.025	≤5.0
Chloride	3.97	250
Chromium	<0.0005	≤0.05
Copper	0.0064	1
Fluoride	0.01	≤1.5
Iron	0.143	≤0.30
Lead	0.000362	≤0.01
Manganese	0.019	≤0.05
Nitrite (as N)	<0.01	10
Selenium	<0.0002	≤0.05
Sodium	3.1	≤200
Sulphate	1.1	<500
Zinc	0.0107	≤5

### **Turbidity**

The *Canadian Drinking Water Guidelines* also require the turbidity to be below 1 NTU. Turbidity is the measure of relative clarity of a liquid. Clarity is important when producing drinking water for human consumption and in many manufacturing uses. The average turbidity within the system was 0.55 NTU.

### **Temperature**

Temperature is described as an aesthetic objective (a parameter that may impair the taste, smell or colour of water) and physical characteristic of water. Gradual variations in water temperature occur throughout the seasons, however significant changes in water temperature can upset chlorination and chemical water treatment processes. The guidelines recommend water temperature to be less than 15°Celsius. The average temperature for the distribution water was 12.5°Celsius.

### **pH**

The pH of water is a measure of water acidity. pH has minimal impact for water consumers and varies greatly depending on the water source. However, pH is very important for many operational water quality parameters. The *Canadian Drinking Water Guidelines* recommend the pH ranging between 6.5-8.5, in 2017, the the average pH within the distribution system was 7.46.




## Planning

### Goals

To ensure effective long-term planning and management programs are in place to meet the needs of all users groups while minimizing operation and infrastructure costs.

### Consumption


The average daily water consumption for the system was 744m<sup>3</sup>/day. A comparison of demands from the past ten years reveals a decrease in the average daily demand while the maximum daily demand has remained almost unchanged. Over the past ten years the highest daily demand has occurred within June, July or August, illustrating that water consumption increases in the summer months. Figure No.4 shows the total yearly consumption for Royston from 2013 to present.



**Figure No.4: Royston Yearly Consumption**

## Maintenance

The Royston Water System is owned and operated by the CVRD. Water services staff consists of eight operators with varying ranges of certification. Each operator is registered with the



environmental operator's certification program within BC and is required to remain in good standing by taking yearly continuing education courses.

The CVRD carries out regular and routine maintenance of the entire Royston Water System, to ensure continued operation and supply of safe and clean water to all users. The chlorination facility, distribution lines and reservoirs are regularly inspected and maintained.

Every service request within the system is investigated by the CVRD's Waterworks Operations Staff and appropriate action is taken. Figure No.5 identifies the breakdown of the various types of service requests received by waterworks staff.

**Figure No.5: Service Requests by Category**

## Financial

In 2017, the CVRD supplied a total of 267,800m<sup>3</sup> of water. Water for the Royston System is supplied in bulk from the Village of Cumberland. The agreement was set to expire at the end of 2017, but the CVRD and the Village of Cumberland have worked together to renew this agreement for another three years. The bulk water rate is scheduled to increase to \$0.76/m<sup>3</sup> in 2018 with one cent increases in 2019 and 2020. No changes to residential and commercial users' water rates occurred in 2017 and no changes are expected before asset management planning for the Royston Water Service is complete in late 2018.

The CVRD completed further review of alternate water supply options in 2017. The study identified possible alternate water sources for the system should the Royston Water System be required to disconnect from the Village of Cumberland's water supply in the future.

Procurement of a consultant to develop a detailed asset management plan for the service was completed in 2017. The plan is expected to be complete by the end of 2018 and will include development of an asset inventory, review of the condition of current infrastructure required levels of service and long term asset replacement requirements. Water rates will be reviewed as part of this work to ensure sufficient revenue is being collected to help fund future upgrades.

Planned projects for 2018 include completion of a detailed asset management plan for the service and replacement of a water main on Gartley and Gartley Point Road to improve fire flows.

## 2017 Accomplishments

- ✓ Completion of further work on the Royston Alternate Source Water Study.
- ✓ Updated three year bulk water supply agreement with the Village of Cumberland.
- ✓ Commencement of a detailed asset management plan for the service.

## 2018 Objectives

- Gartley fire flow improvements.
- Complete a detailed asset management plan for the service.



## Appendix A

Date	DISTRIBUTION SYSTEM												
	Chlorine Residual (mg/L)					E.Coli				Total Coliforms			
	Reservoir Outlet	3269 Kentwood	262 Spindrift	3771 Haas	4090 Gartley	4098 Gartley Pt.	250 Spindrft	3269 Kentwood	Haas Road	4098 Gartley Pt.	250 Spindrft	3269 Kentwod	Haas Road
01-Jan-17													
02-Jan-17													
03-Jan-17				1.1					<1				<1
04-Jan-17													
05-Jan-17													
06-Jan-17													
07-Jan-17													
08-Jan-17													
09-Jan-17	1.67	0.68						<1				<1	
10-Jan-17													
11-Jan-17													
12-Jan-17													
13-Jan-17													
14-Jan-17													
15-Jan-17													
16-Jan-17			0.31				<1				<1		
17-Jan-17													
18-Jan-17													
19-Jan-17													
20-Jan-17													
21-Jan-17													
22-Jan-17													
23-Jan-17						<1				<1			
24-Jan-17													
25-Jan-17													
26-Jan-17													
27-Jan-17													
28-Jan-17													
29-Jan-17													
30-Jan-17									<1				<1
31-Jan-17													
01-Feb-17													
02-Feb-17													
03-Feb-17													
04-Feb-17													
05-Feb-17													
06-Feb-17	1.02	0.43						<1				<1	
07-Feb-17													
08-Feb-17													
09-Feb-17													
10-Feb-17													
11-Feb-17													
12-Feb-17													
13-Feb-17													
14-Feb-17			0.17				<1				<1		
15-Feb-17													
16-Feb-17													
17-Feb-17													
18-Feb-17													
19-Feb-17													
20-Feb-17					0.76	<1				<1			
21-Feb-17													
22-Feb-17													
23-Feb-17													
24-Feb-17													
25-Feb-17													
26-Feb-17													
27-Feb-17													
28-Feb-17									<1				<1
01-Mar-17													
02-Mar-17													
03-Mar-17													
04-Mar-17													
05-Mar-17													

Date	DISTRIBUTION SYSTEM												
	Chlorine Residual (mg/L)					E.Coli				Total Coliforms			
	Reservoir Outlet	3269 Kentwood	262 Spindrift	3771 Haas	4090 Gartley	4098 Gartley Pt.	250 Spindrift	3269 Kentwood	Haas Road	4098 Gartley Pt.	250 Spindrift	3269 Kentwood	Haas Road
06-Mar-17	1.23	0.37						<1				<1	
07-Mar-17													
08-Mar-17													
09-Mar-17													
10-Mar-17													
11-Mar-17													
12-Mar-17													
13-Mar-17							<1				<1		
14-Mar-17													
15-Mar-17													
16-Mar-17													
17-Mar-17													
18-Mar-17													
19-Mar-17													
20-Mar-17					0.69	<1				<1			
21-Mar-17													
22-Mar-17													
23-Mar-17													
24-Mar-17													
25-Mar-17													
26-Mar-17													
27-Mar-17													
28-Mar-17													
29-Mar-17													
30-Mar-17													
31-Mar-17													
01-Apr-17													
02-Apr-17													
03-Apr-17				1.41					<1				<1
04-Apr-17													
05-Apr-17													
06-Apr-17													
07-Apr-17													
08-Apr-17													
09-Apr-17								<1				<1	
10-Apr-17													
11-Apr-17													
12-Apr-17													
13-Apr-17													
14-Apr-17													
15-Apr-17													
16-Apr-17													
17-Apr-17													
18-Apr-17			0.12				<1				<1		
19-Apr-17													
20-Apr-17													
21-Apr-17													
22-Apr-17													
23-Apr-17													
24-Apr-17					0.78	<1				<1			
25-Apr-17													
26-Apr-17													
27-Apr-17													
28-Apr-17													
29-Apr-17													
30-Apr-17													
01-May-17				1.07					<1				<1
02-May-17													
03-May-17													
04-May-17													
05-May-17													
06-May-17													
07-May-17													
08-May-17								<1				<1	

[illegible]



Date	DISTRIBUTION SYSTEM												
	Chlorine Residual (mg/L)					E.Coli				Total Coliforms			
	Reservoir Outlet	3269 Kentwood	262 Spindrift	3771 Haas	4090 Gartley	4098 Gartley Pt.	250 Spindrift	3269 Kentwood	Haas Road	4098 Gartley Pt.	250 Spindrift	3269 Kentwod	Haas Road
12-Jul-17													
13-Jul-17													
14-Jul-17													
15-Jul-17													
16-Jul-17													
17-Jul-17			0.79				<1				<1		
18-Jul-17													
19-Jul-17													
20-Jul-17													
21-Jul-17													
22-Jul-17													
23-Jul-17													
24-Jul-17					1.05				<1				<1
25-Jul-17													
26-Jul-17													
27-Jul-17													
28-Jul-17													
29-Jul-17													
30-Jul-17				0.85									
31-Jul-17						<1				<1			
01-Aug-17													
02-Aug-17													
03-Aug-17													
04-Aug-17													
05-Aug-17													
06-Aug-17													
07-Aug-17													
08-Aug-17	1.08	0.62						<1				<1	
09-Aug-17													
10-Aug-17													
11-Aug-17													
12-Aug-17													
13-Aug-17													
14-Aug-17							<1				<1		
15-Aug-17													
16-Aug-17													
17-Aug-17													
18-Aug-17													
19-Aug-17													
20-Aug-17													
21-Aug-17	1.08	0.67						<1				<1	
22-Aug-17													
23-Aug-17													
24-Aug-17													
25-Aug-17													
26-Aug-17													
27-Aug-17													
28-Aug-17				0.56					<1				<1
29-Aug-17													
30-Aug-17													
31-Aug-17													
01-Sep-17													
02-Sep-17													
03-Sep-17													
04-Sep-17													
05-Sep-17				0.63					<1				<1
06-Sep-17													
07-Sep-17													
08-Sep-17													
09-Sep-17													
10-Sep-17													
11-Sep-17	0.64	0.33						<1				<1	
12-Sep-17													
13-Sep-17													

[illegible]

[illegible]