

Notice of Meeting # 8 of the  
**LIQUID WASTE MANAGEMENT PLAN**  
**JOINT TECHNICAL AND PUBLIC ADVISORY COMMITTEES (TACPAC)**

Thursday, December 5, 2019  
CVRD Boardroom, 600 Comox Road  
9:00 am - 3:00 pm

| ITEM, TIME                 | DESCRIPTION  | OWNER                       |
|----------------------------|--|-----------------------------|
| 8.1<br>9:00                | Call to Order  | Allison Habkirk             |
| 8.2<br>9:00-9:10           | Review of Minutes of Meeting #7  | Allison Habkirk             |
| 8.3<br>9:10-9:50           | K'ómoks First Nation Archeological History   | Jesse Morin                 |
| Break                      |  |                             |
| 8.4<br>10:00-10:30         | Review of Approval Process <ul style="list-style-type: none"> <li>Discussion on approval process of preferred options for conveyance and treatment</li> </ul>  | Paul Nash & Allison Habkirk |
| 8.5<br>10:30-11:15         | Short List Options - Treatment - Technical <ul style="list-style-type: none"> <li>Review of capacity upgrades and levels of treatment options</li> <li>Explanation of technical attributes</li> </ul>  | WSP                         |
| 8.6<br>11:15-12:00         | Short List Options - Treatment - Financial <ul style="list-style-type: none"> <li>Explanation and review of financial modelling</li> </ul>   | WSP & CVRD                  |
| Lunch Break<br>12:00-12:30 |  |                             |
| 8.7<br>12:30-2:45          | Evaluating Short List Options - Treatment <ul style="list-style-type: none"> <li>Review of evaluation system</li> <li>Staff summary of option attributes for economic, environmental and social categories</li> <li>Evaluate the options</li> <li>Discussion</li> <li>Finalize preferred level of treatment decision</li> </ul> <p><b><i>Make a recommendation to the Comox Valley Sewage Commission on the preferred level of treatment for the Comox Valley Water Pollution Control Center</i></b></p> | Paul Nash & Allison Habkirk |
| 8.8<br>2:45-3:00           | LWMP Schedule Update <ul style="list-style-type: none"> <li>Next steps for treatment, conveyance and public communication</li> </ul>   | Paul Nash & Kris La Rose    |
| 8.9<br>3:00                | Adjournment  | Allison Habkirk             |

**Attachments:**

1. Minutes of TAC Meeting #7, September 30, 2019
2. Stage 2 Wastewater Treatment Assessment, WSP

Minutes of the meeting of the Liquid Waste Management Plan (LWMP) Joint Technical and Public Advisory Committees (TACPAC) Meeting #7 held on Monday, September 30, 2019 at the Comox Valley Regional District (CVRD) Boardroom, commencing at 1:00 pm.

|                 |   |                         |
|-----------------|---|-------------------------|
| <b>PRESENT:</b> | A. Habkirk, Chair and Facilitator                     |                         |
|                 | P. Nash, LWMP Project Coordinator                     |                         |
|                 | M. Rutten, General Manager Engineering Services       | CVRD                    |
|                 | K. La Rose, Senior Manager of Water/Wastewater        | CVRD                    |
|                 | M. Imrie, Manager of Wastewater Services              | CVRD                    |
|                 | J. Wallis, Branch Assistant – Engineering Services    | CVRD                    |
|                 | Z. Berkey, Engineering Analyst                        | CVRD                    |
|                 | C. Engisch  | Baseline Archaeological |
|                 | A. Bennett  | WSP                     |
|                 | C. Campbell   | WSP                     |
|                 | D. Grimes   | MJA                     |
|                 | M. Swift, Town of Comox Councillor                    | PAC                     |
|                 | W. Cole-Hamilton, City of Courtenay Councillor        | PAC                     |
|                 | A. Hamir, Lazo North – Electoral Area B Director      | PAC                     |
|                 | M. Horton, K'ómoks First Nation                       | PAC/TAC                 |
|                 | A. Gower, Comox Valley Chamber of Commerce            | PAC                     |
|                 | E. Nowak, CV Conservation Partnership Alternate       | PAC                     |
|                 | H. Dewhirst, Comox Business Improvement Association   | PAC                     |
|                 | S. Carey, Courtenay Resident Representative           | PAC                     |
|                 | K. Niemi, Courtenay Resident Representative           | PAC                     |
|                 | K. vanVelzen, Comox Resident Representative           | PAC                     |
|                 | D. Jacquest, Comox Resident Representative            | PAC                     |
|                 | R. Craig, Comox Resident Representative               | PAC                     |
|                 | D. Winterburn, BC Shellfish Growers Association       | PAC                     |
|                 | J. Steel, Area B Resident Representative Alternate    | PAC                     |
|                 | L. Aitken, Area B Representative Alternate (observer) | PAC                     |
|                 | M. Lang, Area B Resident Representative               | PAC                     |
|                 | R. O'Grady, City of Courtenay Engineering             | TAC                     |
|                 | S. Ashfield, Town of Comox Engineering                | TAC                     |

| ITEM | DESCRIPTION  | OWNER           |
|------|--|-----------------|
| 7.1  | <b>Call to Order</b> <ul style="list-style-type: none"> <li>Meeting called to order at 1:00pm</li> </ul>   | Allison Habkirk |
| 7.2  | <b>Round Table of Introductions</b>  | Allison Habkirk |
| 7.3  | <b>Review of Minutes of Meeting #6 and #6A</b> <ul style="list-style-type: none"> <li>Not stated in minutes is the decision if Option 3C will require a pump station due to the elevation of gravity lines (page 6 of technical impacts). – K. vanVelzen</li> <li>Not reflected in minutes are the discussions regarding the combination of Options 3A, 3B, 3C, to one single option – K. vanVelzen</li> </ul> | Allison Habkirk |

| ITEM | DESCRIPTION   | OWNER  |
|------|---|--|
| 7.3  | <ul style="list-style-type: none"> <li>• Incorrect spelling of Don Jaquest's name, page 4 and 5 of the meeting minutes – R. Craig</li> <li>• Incorrect spelling of the word 'unseeded' (unceded) on page two of the #6 meeting minutes – R. Craig</li> </ul> <p>MOTION: With items noted, minutes of meeting #6 and #6A be adopted – R. Craig<br/> SECONDED: K. vanVelzen<br/> CARRIED</p>  | Allison Habkirk  |
| 7.4  | <p><b>Update on LWMP Process and Current Status</b><br/> Kris La Rose, provided an update to TACPAC members on what the LWMP project team has been working on since meeting #6 &amp; #6A, including K'ómoks First Nation (KFN) consultation, follow-up odour dispersion modelling and a review of Area 'B' representation on Comox Valley Sewage Commission.</p> <p>Presentation: Comox Valley Sewage Service Liquid Waste Management Plan</p> <p>Comments</p> <ul style="list-style-type: none"> <li>• Is there a policy for KFN's role on Sewage Commission? – A.Hamir <ul style="list-style-type: none"> <li>○ Recommendation carried at the Sewage Commission meeting dated September 17, 2019: D. Hillian/K. Grant: THAT the Sewage Commission invite the K'ómoks First Nation to appoint an observer to the Sewage Commission, thereby helping to broaden awareness on all parties and to assist KFN with improving its ability to participate in decision-making for key community infrastructure.<br/> – M. Rutten</li> </ul> </li> <li>• Will there be a similar policy that we have with KFN for Electoral Area B – A. Hamir <ul style="list-style-type: none"> <li>○ There was a similar motion carried at the Sewage Commission meeting dated September 17, 2019: D. Hillian/K. Grant: THAT the Sewage Commission direct staff to develop a policy through which the Electoral Area B (Lazo North) Director is invited to attend Sewage Commission meetings, in a defined capacity, to speak to and ask questions around specific topics that relate to the infrastructure and operations located in Electoral Area B.<br/> - K. La Rose</li> </ul> </li> <li>• If a referendum was held that failed, what would become of the project? – M. Swift <ul style="list-style-type: none"> <li>○ Regulatory drivers and constraints still exist, so an analysis of the project and recommendations would be brought forward to the Sewage Commission for decision. – K. La Rose</li> </ul> </li> </ul> | Kris La Rose   |
| 7.5  | <p><b>K'ómoks First Nation – Archeology</b><br/> Chris Engisch provided an overview of the archeological sites and permitting requirements.</p>   | Chris Engisch,<br>Baseline<br>Archaeological<br>Services |

| ITEM | DESCRIPTION   | OWNER  |
|------|---|--|
| 7.5  | <p>Presentation: Archaeological Overview of LWMP</p> <p>Comments</p> <ul style="list-style-type: none"> <li>• Would this archeological project provide the committee advanced archeological information prior to the implementation of the Liquid Waste Management Plan – A. Habkirk               <ul style="list-style-type: none"> <li>○ Yes, to some extent – C. Engisch</li> </ul> </li> <li>• What would the tunnelling and permitting requirements be through First Nations lands? – R. O’Grady               <ul style="list-style-type: none"> <li>○ Because of project size, this will have to be discussed with the KFN and the Province. – C. Engisch</li> </ul> </li> <li>• Could there be any archeological findings outside KFN land and what happens if archaeological artifacts are found outside KFN? – S. Carey               <ul style="list-style-type: none"> <li>○ Yes, most of the foreshore around the estuary falls within known archeologically sensitive areas. The likelihood of finding remains off the foreshore are less. Permits will be in place for all excavation within known archeological zones – C. Engisch</li> <li>○ Chance find protocols would be in place for all excavation . – A. Gower</li> </ul> </li> </ul>   | Chris Engisch,<br>Baseline<br>Archaeological<br>Services |
| 7.6  | <p><b>Treatment Technical Memorandums</b></p> <p>Aline Bennett, WSP, updated the committee on technical processes, and reviewed the treatment technical memorandums, provided as part of the agenda, on emerging contaminants, micro plastics and viruses.</p> <p>Presentation: An Overview of Microplastics, Emerging Contaminant and Viruses in Wastewater</p> <p>Comments</p> <p>Micro-Plastics:</p> <ul style="list-style-type: none"> <li>• With the application of SkyRocket, will the micro plastics be recycling through the process? R. Craig               <ul style="list-style-type: none"> <li>○ Not aware if micro-plastics will wash out of soil and be reintroduced in the process. – A. Bennett</li> </ul> </li> </ul> <p>Emerging Contaminants of Concern:</p> <ul style="list-style-type: none"> <li>• Is anyone in Canada measuring CEC’s in effluent to understand what kinds of chemicals are getting through? Have we measured our own effluent to see how we compare? – D. Jacquest               <ul style="list-style-type: none"> <li>○ Mainly relying on the European experience. Measuring of CEC’s is somewhat understood but not well known. – A. Bennett</li> <li>○ We have not sampled for CEC’s in our effluent, it is not routinely sampled in Canada and is very expensive to do so.. – M. Imrie</li> <li>○ Not aware of any continuous sampling in Canada, but there have been several “spot” studies at WWPT’s. – P. Nash</li> <li>○ Cannot stop consumers using materials, but can encourage different types of disposal to limit load. – M. Rutten</li> </ul> </li> </ul> | WSP  |

| ITEM | DESCRIPTION  | OWNER                            |
|------|--|----------------------------------|
| 7.6  | <ul style="list-style-type: none"> <li>○ Main loads come through the body to the effluent stream.<br/>- A. Bennett</li> <li>• Request upgrade costs in comparison to Quebec and Montreal plant secondary treatment system – R. O’Grady</li> </ul> <p>Viruses:</p> <ul style="list-style-type: none"> <li>• Committed to install disinfection system at facility. This work will help develop needs. – K. La Rose</li> <li>• Would ultra-violet (UV) system transfer environmental costs/risks, have unintended consequences? – M. Lang               <ul style="list-style-type: none"> <li>○ Different forms of treatment can result in different disinfection by-products being formed. UV systems are generally used as disinfection by products aren’t produced as part of the process. – A. Bennett</li> </ul> </li> <li>• MSC’s no longer proven to be effective indicator of Norovirus – D. Winterburn               <ul style="list-style-type: none"> <li>○ WSP, A.Bennett to follow-up after meeting</li> </ul> </li> <li>• Page 5 on the report on Viruses talks about the possibility of PAA. – D. Jacquest               <ul style="list-style-type: none"> <li>○ PAA is an emerging science and could be possible – A. Bennett</li> </ul> </li> </ul>  | WSP                              |
| 7.7  | <p>Conveyance – Tunnelling 101<br/>Doug Grimes, McMillen Jacobs Associates and Carol Campbell, WSP, reviewed the different trenchless technologies for conveyance.</p> <p>Presentation: CVRD – Liquid Waste Management Plan, Trenchless Conveyance Options</p> <p>Comments</p> <ul style="list-style-type: none"> <li>• Why the cost variance between options? – D. Jacquest               <ul style="list-style-type: none"> <li>○ Presenting order of magnitude costs for the varying tunnelling technologies – Doug Grimes</li> </ul> </li> <li>• Have contingency numbers been included in the cost summary? – R. O’Grady:               <ul style="list-style-type: none"> <li>○ There could be cost variances because of substructure and other unknown factors – soil type can be quite variable. – D. Grimes</li> <li>○ Cost variance also depends on the total length to drill. – C. Campbell</li> </ul> </li> <li>• What is the assumption on the length of tunnel? – Don Jacquest               <ul style="list-style-type: none"> <li>○ Working on optimizing the tunnel solution to minimize cost but maximize benefits of tunnelling. – D. Grimes/C. Campbell</li> </ul> </li> <li>• What is the cost comparison of trenchless technologies to open cut – R. O’Grady               <ul style="list-style-type: none"> <li>○ Open cut is the most cost effective in terms of up front capital – C. Campbell</li> </ul> </li> <li>• What are the land use implications for obtaining right of way’s – R. O’Grady               <ul style="list-style-type: none"> <li>○ We are working with a consultant, D. Aberdeen on this portion of work, our understanding is the process is similar to</li> </ul> </li> </ul> | WSP & McMillen Jacobs Associates |

| ITEM | DESCRIPTION  | OWNER                            |
|------|--|----------------------------------|
| 7.7  | <p>establishing Statutory Right of Ways for traditional cut and cover projects. – K. La Rose</p> <ul style="list-style-type: none"> <li>• Are pricing options going to be revised based on review of tunnelling technologies? – A. Gower <ul style="list-style-type: none"> <li>○ Yes they will. – C. Campbell</li> </ul> </li> <li>• How much cover is needed when drilling under a house/building? – P. Nash <ul style="list-style-type: none"> <li>○ Two to three meters minimum. – D. Grimes</li> </ul> </li> <li>• How deep will the pipe be? – M. Horton <ul style="list-style-type: none"> <li>○ Currently reviewing the depth of pipe, roughly around 20 meters at deepest points but again, reviewing to try and optimize tunnelling solution. – D. Grimes</li> </ul> </li> <li>• What is the normal amount of geotechnical investigations needed to reduce risk ahead of construction? – M. Rutten <ul style="list-style-type: none"> <li>○ Preliminary investigation usually includes four boreholes per each alignment, depending on the results more may be required if the samples show variability. – D. Grimes</li> </ul> </li> <li>• What is the project delivery model that will be used for the conveyance portion of the LWMP and what is the role that McMillen Jacobs usually plays on projects? – R. O’Grady <ul style="list-style-type: none"> <li>○ McMillen Jacobs typically works as an owners engineer for design build projects or manages design and engineering for design bid build projects. – D. Grimes</li> <li>○ This project is likely to be delivered as design bid build, but a procurement options analysis will be undertaken before settling on a project delivery method. – K. La Rose</li> </ul> </li> </ul> | WSP & McMillen Jacobs Associates |
| 7.8  | <p>Review of Next Steps</p> <ul style="list-style-type: none"> <li>• Considering archeological impacts could be added as evaluation criteria. Discussion on if TACPAC are in favour to consider. <ul style="list-style-type: none"> <li>○ Could be included/ considered under existing social benefits criteria – D. Jacquest</li> <li>○ Could be considered as part of technical discussion as well – R. O’Grady</li> </ul> </li> <li>• Will be working with KFN on conveyance options ahead of next TACPAC meeting, so timing is not entirely known.</li> <li>• Next meeting to be arranged as soon as possible - three to four weeks of notice will be provided. Meeting could discuss conveyance or treatment depending on consultation with KFN.</li> </ul>   | Kris La Rose                     |
| 7.9  | Meeting Adjourned  |                                  |

## MEMO

**TO:** CVRD LWMP TACPAC Committee

**CC:** Kris La Rose, P.Eng., CVRD, Zoe Berkey, EIT, CVRD, Paul Nash

**FROM:** Tyler Barber, MAsC, P.Eng., Aline Bennett, MAsC, P.Eng., Al Gibb, PhD, P.Eng.

**SUBJECT:** CVRD LWMP – Stage 2 Wastewater Treatment Level Assessments

**DATE:** November 26, 2019

---

## INTRODUCTION

The Comox Valley Regional District (CVRD) has retained WSP Canada Group Ltd. to complete the Liquid Waste Management Plan (LWMP) for the District. As part of the work, WSP has completed the Stage 2 wastewater assessment for the Comox Valley Water Pollution Control Centre (CVWPCC). This work is a high-level review of the estimated capacity of the existing infrastructure at the CVWPCC, what is required for expansion to handle 2040 flows and loads into the CVWPCC, and costing different level of wastewater treatment options for the CVWPCC.

This memo provides the following information:

- Updated CVWPCC population, flow and load projections;
- High-level review of the capacity of each unit process (attached in the Appendix);
- Cost estimates and preliminary site plans for upgrading the plant to meet 2040 capacity requirements and providing different levels of wastewater treatment including:
  - Option 1: not advanced from the long-list
  - Option 2: Secondary treatment for entire flow with disinfection (base case)
  - Option 3: Addition of advanced treatment for 2xADWF
  - Option 4: Addition of advanced treatment for the entire flow
  - Option 5: Addition of reclaimed water for in plant use, which can be common to all options

The objective of this assessment is to enable decision making on the appropriate level of wastewater treatment to provide at the CVWPCC by comparing the costs and benefits of the different options. The *CVWPCC Capacity Assessment* completed by ISL Engineering and Land Services in 2016, was a significant input to this assessment.

## POPULATION, FLOW AND LOAD PROJECTIONS

### CVWPCC POPULATION PROJECTIONS

Population for the CVWPCC service area is projected based on expected growth rates for the area. Current service areas to the CVWPCC include the City of Courtenay, the Town of Comox, CFB Comox and K'ómoks First Nation (KFN). Historical population for the City of Courtenay and the Town of Comox (includes KFN) was obtained from the BC Stats database. According to the 2016 ISL *CVWPCC Capacity Assessment* report, future connections to the CVWPCC service area

include 400 single-family units referred to as the CVRD Annexation, this is also included in the population assessment shown in Table 1. Service area growth is projected using the annual growth rates used by ISL in their 2016 *CVWPCC Capacity Assessment*. Table 1 shows the historical and projected populations for the service area.

*Table 1: Historical and Projected Population to Year 2060*

| YEAR                        | CITY OF<br>COURTENAY <sup>1</sup> | TOWN OF<br>COMOX <sup>2</sup> | CFB COMOX | CVRD<br>ANNEXATION <sup>3</sup> | K'OMOKS<br>FIRST<br>NATION <sup>4</sup> | TOTAL  |
|-----------------------------|-----------------------------------|-------------------------------|-----------|---------------------------------|---|--------|
| 2013                        | 24,815                            | 13,933                        | 966       | -                               |   | 39,714 |
| 2014                        | 25,187                            | 14,216                        | 966       | -                               |   | 40,369 |
| 2015                        | 25,782                            | 14,518                        | 966       | -                               |   | 41,266 |
| 2016                        | 26,736                            | 14,652                        | 966       | -                               |   | 42,354 |
| 2017                        | 27,146                            | 14,850                        | 966       | -                               |   | 42,962 |
| 2018                        | 27,533                            | 14,706                        | 966       | -                               | 293                                     | 43,498 |
| 2019                        | 28,117                            | 14,994                        | 966       | -                               | 293                                     | 44,370 |
| <b>Projected Population</b> |                                   |                               |           |                                 |   |        |
| 2020                        | 28,713                            | 15,281                        | 966       |                                 | 299                                     | 45,259 |
| 2030                        | 33,053                            | 17,558                        | 966       | 1,098                           | 343                                     | 53,018 |
| 2040                        | 37,759                            | 20,057                        | 966       | 1,274                           | 392                                     | 60,448 |
| 2050                        | 43,135                            | 22,913                        | 966       | 1,478                           | 448                                     | 68,940 |
| 2060                        | 49,277                            | 26,176                        | 966       | 1,716                           | 511                                     | 78,645 |

1 2020 – 2021 growth rate of 2.12% and 2022 – Future growth rate of 1.34% from ISL 2016

2 2020 – 2021 growth rate of 1.92% and 2022 – Future growth rate of 1.34% from ISL 2016

3 2020 – Future growth rate of 1.5% used from ISL 2016

4 Assuming 122 units, with 2.4 people per connection. Growth rate of 1.34% . .

## FLOW PROJECTIONS

The 2013 to 2017 flow rates provided in Table 2 were used to generate average per capita flow rates into the CVWPCC. These were applied to future year population projections to determine future flow rates to year 2060. The flow rates were determined as follows:

- Average Dry Weather Flow (ADWF): Minimum 30-day rolling average flow for the year;
- Average Daily Flow (ADF): Average flow during the year;
- Average Wet Weather Flow (AWWF): Maximum 30-day rolling average flow for the year;
- Max day flow (MDF): Maximum single day flow in the year;
- Peak Hourly Flow (PHF): Peaking factor developed by ISL (2016) was used to determine projected PHF (3.0 x ADF); and
- Maximum Instantaneous Flow: Peaking factor developed by ISL (2016) was used to determined projected maximum instantaneous flow (3.2 x ADF).



Table 2: Historical Flows, 2013-2017

| Year    | Population | HISTORICAL FLOWS <sup>1</sup> , M <sup>3</sup> /DAY |        |        |        | UNIT FLOWS, L/C/D |     |      |     |
|---------|------------|---|--------|--------|--------|-------------------|-----|------|-----|
|         |            | ADWF  | ADF    | AWWF   | MDF    | ADWF              | ADF | AWWF | MDF |
| 2013    | 39,714     | 12,142  | 13,249 | 15,029 | 21,225 | 306               | 334 | 378  | 534 |
| 2014    | 40,369     | 11,906  | 14,221 | 20,000 | 38,462 | 295               | 352 | 495  | 953 |
| 2015    | 41,266     | 11,504  | 13,732 | 21,914 | 37,253 | 279               | 333 | 531  | 903 |
| 2016    | 42,354     | 11,518  | 15,462 | 23,533 | 39,998 | 272               | 365 | 556  | 944 |
| 2017    | 42,962     | 11,694  | 14,328 | 19,650 | 34,965 | 272               | 334 | 457  | 814 |
| Average |            |   |        |        |        | 285               | 343 | 484  | 830 |

1 From Daily Influent Plant Data.

With the data available to WSP at the time of completing this memo, PHF and maximum instantaneous flow were not able to be determined with the data, therefore the peaking factors from ISL (2016) were used. Table 3 shows these projected future flows from 2020 to 2060. These flow projections use the same per capita flows determined in Table 3.

Table 3: Flow Projections, 2020-2060

|   | 2020   | 2030   | 2040   | 2050   | 2060   |
|---|--------|--------|--------|--------|--------|
| <b>Population Projection</b>              | 45,259 | 53,018 | 60,448 | 68,940 | 78,645 |
| <b>Flow Projections</b>                   |        |        |        |        |        |
| Average Dry Weather Flow (ADWF) (m3/d)    | 12,885 | 15,094 | 17,210 | 19,627 | 22,390 |
| Average Day Flow (ADF) (m3/d)             | 15,542 | 18,206 | 20,758 | 23,674 | 27,007 |
| Average Wet Weather Flow (AWWF) (m3/d)    | 21,887 | 25,640 | 29,233 | 33,339 | 38,033 |
| Max Day Flow (MDF) (m3/d)                 | 37,547 | 43,984 | 50,148 | 57,193 | 65,244 |
| Peak Hour Flow <sup>1</sup> (PHF) (m3/d)  | 46,626 | 54,619 | 62,274 | 71,022 | 81,020 |
| Maximum Instantaneous <sup>2</sup> (m3/d) | 49,734 | 58,260 | 66,425 | 75,757 | 86,421 |
| Maximum Instantaneous (L/s)               | 576    | 674    | 769    | 877    | 1,000  |

1 Peaking Factor of 3.0 was adapted from the ISL CVWPCC Capacity Assessment (2016).

2 Peaking Factor of 3.2 was adapted from the ISL CVWPCC Capacity Assessment (2016).

## LOAD PROJECTIONS

Table 4 summarizes the historical (2013 to 2017) influent 5-day Biochemical Oxygen Demand (BOD<sub>5</sub>) and Total Suspended Solids (TSS) loadings used to develop average per capita unit loading rates. The BOD<sub>5</sub> data are taken from weekly composite samples. Total Suspended Solids (TSS) samples are assumed to be grab samples that were taken approximately 3 – 4 times per week for the duration of the time periods indicated. Average BOD<sub>5</sub> and TSS loads are shown in Table 4.



Table 4: Historical Influent Loading, 2013-2017

| HISTORICAL INFLUENT LOADING <sup>1</sup><br>KG/D |                         |                          |                            |             |               | INFLUENT UNIT LOADING<br>G/C/D |                            |             |               |
|--|-------------------------|--------------------------|----------------------------|-------------|---------------|--------------------------------|----------------------------|-------------|---------------|
| Year   | Population <sup>2</sup> | Average BOD <sub>5</sub> | Max Month BOD <sub>5</sub> | Average TSS | Max Month TSS | Average BOD <sub>5</sub>       | Max Month BOD <sub>5</sub> | Average TSS | Max Month TSS |
| 2013   | 39,714                  | 3,327                    | 4,085                      | 3,425       | 4,383         | 84                             | 103                        | 86          | 110           |
| 2014   | 40,369                  | 3,720                    | 8,983                      | 4,144       | 6,198         | 92                             | 223                        | 103         | 154           |
| 2015   | 41,266                  | 3,675                    | 5,641                      | 3,977       | 5,351         | 89                             | 137                        | 96          | 130           |
| 2016   | 42,354                  | 2,605                    | 6,919                      | 4,412       | 6,988         | 62                             | 163                        | 104         | 165           |
| 2017   | 42,962                  | 2,946                    | 4,306                      | 4,116       | 5,189         | 69                             | 100                        | 96          | 121           |
| Average  |                         |                          |                            |             |               | 79                             | 145                        | 97          | 136           |

1 Plant Data. We have assumed this data includes all return streams from the plant.

2 Population was obtained from BC Stats.

The average per capita loading for BOD<sub>5</sub> and TSS were rounded to 80 and 100 g/c/d. These values compare to the ISL (2016) per capita values used of 90 g/c/d and 100 g/c/d for BOD<sub>5</sub> and TSS, respectively. We have assumed that the loads from ISL (2016) and the data WSP analyzed includes the additional loading received from septage and return flows in the plant.

We note that the peaking factor between average and max month BOD<sub>5</sub> per capita loading (1.8) is more than what would be expected for typical domestic wastewater. Therefore, we have removed the 223 g/c/d data point for the year 2014 and are using an average max month per capita loading of 126 g/c/d for BOD<sub>5</sub>. TSS max month loading was found to be 136 g/c/d. This compares with the max month loading from ISL (2016) of 117 g/c/d and 120 g/c/d for BOD<sub>5</sub> and TSS, respectively.

No data was available for Total Kjeldahl Nitrogen (TKN), therefore loading data is based on per capita unit rates from ISL (2016). The TKN loading determined in ISL (2016) was based on 13 g/c/d, which is considered typical for domestic wastewater without any industrial loading. They also determined a peaking factor of 1.1 between average and max month loading. These same values were carried forward for projecting TKN load to the CVWPCC. Table 5 shows the projected future loads to the CVWPCC for BOD<sub>5</sub>, TSS, and TKN.

Table 5: Load Projections, 2020-2060

|                                   | 2020   | 2030   | 2040   | 2050   | 2060   |
|-----------------------------------|--------|--------|--------|--------|--------|
| <b>Population Projection</b>      | 45,259 | 53,018 | 60,448 | 68,940 | 78,645 |
| <b>Load Projections</b>           |        |        |        |        |        |
| <b>BOD<sub>5</sub></b>            |        |        |        |        |        |
| Average BOD <sub>5</sub> (kg/d)   | 3,621  | 4,241  | 4,836  | 5,515  | 6,292  |
| Max month BOD <sub>5</sub> (kg/d) | 5,693  | 6,669  | 7,603  | 8,672  | 9,892  |
| <b>TSS</b>                        |        |        |        |        |        |
| Average TSS (kg/d)                | 4,526  | 5,302  | 6,045  | 6,894  | 7,865  |
| Max month TSS (kg/d)              | 6,155  | 7,210  | 8,221  | 9,376  | 10,696 |
| <b>TKN</b>                        |        |        |        |        |        |
| Average TKN (kg/d)                | 588    | 689    | 786    | 896    | 1,022  |
| Max month TKN (kg/d)              | 647    | 758    | 864    | 986    | 1,125  |

## CVWPCC UPGRADE OPTIONS

### EXITING WASTEWATER TREATMENT SYSTEM

The CVWPCC is a secondary treatment level activated sludge plant that was constructed in 1982 and receives flow from five (5) pump stations. The plant has the following treatment processes at the facility:

- Preliminary treatment with two coarse bar screens and three pre-aeration grit removal tanks;
- Three primary clarifiers;
- Three activated sludge aeration basins;
- Three secondary clarifiers;
- Effluent outfall and pump station for peak flows;
- Two gravity thickeners for the primary sludge (PS);
- Two dissolved air flotation (DAF) units for waste activated sludge (WAS) thickening;
- One combined (PS and WAS) thickened sludge storage tank;
- Two centrifuges for dewatering;
- Ancillary process such as odour control and grit classification.

A capacity assessment for each unit process is provided in the Appendix, which reviews the technical details for each of the unit processes and estimates the capacity for treatment. This assessment did not investigate the condition of the assets and assumes any infrastructure planned for reuse is in a serviceable condition.

### OPTIONS FOR ASSESSMENT

The following options (Table 6) were developed from the Stage 1 LWMP long-list in January 2019. All the options, except for Option 1 were advanced to the Stage 2 shortlist for more detailed assessment. Option 1 was not carried forward since it represents a step-back from the existing treatment system.

Table 6: Options for Assessment

| OPTION  | DESCRIPTION  | ADVANCE<br>TO STAGE 2? |
|---|--|------------------------|
| <b>Option 1 – Secondary treatment for flows up to 2xADWF with disinfection</b>      | <p>Secondary treatment for flows up to 2 x ADWF:</p> <ul style="list-style-type: none"> <li>– 5-Day BOD<sub>5</sub>: Max day &lt;45 mg/L; monthly average &lt;25 mg/L</li> <li>– TSS: Max day &lt;45 mg/L, monthly average &lt;25 mg/L</li> <li>– pH 6 – 9</li> <li>– Ammonia does not cause chronic toxicity at the edge of the IDZ</li> <li>– Total residual chlorine &lt; 0.02 mg/L</li> <li>– Un-ionized ammonia &lt; 1.25 mg/L at 15C</li> <li>– Disinfection – fecal coliforms not to exceed 200 MPN/100 mL (end of pipe)</li> </ul> <p>Primary treatment for flows in excess of 2 x ADWF:</p> <ul style="list-style-type: none"> <li>– 5-day BOD<sub>5</sub>: Max day &lt;130 mg/L</li> <li>– TSS: Max day &lt; 130 mg/L</li> <li>– In this scenario, with flows &gt;2xADWF are bypassed from secondary treatment and the flows occur during a storm with less than a 5-year return period, a discharger must have a liquid waste management plan in place and implement the plan or study's measures.</li> </ul> | No                     |
| <b>Option 2 - Secondary treatment for entire flow with disinfection (base case)</b> | <p>Secondary treatment for the entire plant flow:</p> <ul style="list-style-type: none"> <li>– 5-Day BOD<sub>5</sub>: Max day &lt;45 mg/L; monthly average &lt;25 mg/L</li> <li>– TSS: Max day &lt;45 mg/L, monthly average &lt;25 mg/L</li> <li>– pH 6 – 9</li> <li>– Ammonia does not cause chronic toxicity at the edge of the IDZ</li> <li>– Total residual chlorine &lt; 0.02 mg/L</li> <li>– Un-ionized ammonia &lt; 1.25 mg/L at 15C</li> <li>– Disinfection – fecal coliforms not to exceed 200 MPN/100 mL (end of pipe)</li> </ul>  | Yes                    |
| <b>Option 3 – Addition of advanced treatment for 2xADWF</b>                         | <p>Secondary treatment for the entire plant flow (as outlined in Option 2 – Base Case), and also include:</p> <ul style="list-style-type: none"> <li>– Advanced treatment filtration of the secondary treated effluent up to 2 x ADWF</li> <li>– UV disinfection to &lt; 200 MPN/100 mL for all flows (end of pipe): 2xADWF treated to a disk filter level blended with flows that bypass the disk filter at a secondary level of treatment.</li> </ul>  | Yes                    |
| <b>Option 4 - Addition of advanced treatment for entire flow</b>                    | <p>Secondary treatment for the entire plant flow (as outlined in Option 2 – Base Case), and also include:</p> <ul style="list-style-type: none"> <li>– Advanced treatment filtration of the entire secondary treatment flow</li> <li>– UV disinfection on all wastewater at disk filter quality.</li> </ul>  | Yes                    |
| <b>Option 5 – Reclaimed Water</b>   | Reclaimed water for in-plant use. Can be applied to any of Options 2, 3 or 4.  | Yes                    |

## DESIGN CRITERIA

The options outlined in the following sections are based on the following design conditions and information available at the time of completing this assessment:

- Design horizon: 20-year design horizon to 2040
- Flows and loads as outlined for year 2040 in Table 3 and Table 5.
- We have assumed similar technologies that are currently in use will be used for expansion and have not compared other possible process options for treatment.
- Disinfection is to be included.
- Provincial and Federal effluent quality requirements are applicable, as outlined in Table 7.
- The purpose of this review is to provide sufficient information to decide on the treatment level to be installed at the CVWPCC.

*Table 7: Effluent Quality Criteria*

| EFFLUENT PARAMETER              | PROVINCIAL REQUIREMENTS<br>(MWR)                                 | FEDERAL REQUIREMENTS<br>(WSER)                                |
|---------------------------------|--|---|
| 5-day Biochemical Oxygen Demand | Max day < 45 mg/L  | Monthly average < 25 mg/L                                     |
| Total Suspended Solids (TSS)    | Max day < 45 mg/L  | Monthly average < 25 mg/L<br>(carbonaceous BOD <sub>5</sub> ) |
| pH                              | 6 – 9  | N/A   |
| Un-Ionized Ammonia              | N/A  | <1.25 mg/L  |
| Total Residual Chlorine         | N/A  | <0.02 mg/L  |
| Fecal Coliforms <sup>1</sup>    | <14 MPN/100 mL at the edge of the<br>initial dilution zone (IDZ) | N/A   |

<sup>1</sup> Requirements for shellfish receiving waters

## OPTION 2 – SECONDARY TREATMENT WITH DISINFECTION FOR ENTIRE FLOW

Option 2 is the base case scenario that will provide secondary treatment for the entire wastewater flow, as is currently the case at the CVWPCC. The provincial and federal effluent criteria outlined in Table 7 are used in addition to the capacity in the existing system to determine upgrades required to provide capacity until 2040.

A UV disinfection system is included to disinfect the wastewater to a 200 MPN/100 mL fecal coliform concentration at the end of the outfall pipe. Based on the dilution modelling in the Initial Dilution Zone (IDZ), there will be sufficient dilution at the edge of the IDZ to stay below the 14 MPN/100 mL requirement for protection of shellfish. The design criteria for the UV system are shown in Table 8.

*Table 8: UV System Design Criteria*

### CRITERIA

|  |         |
|--|---------|
| No. of Units   | 2       |
| Design Flow: 2040 75% PHF per Unit (m <sup>3</sup> /d) | 46,706  |
| Influent TSS   | 30 mg/L |
| UV Transmittance <sup>1</sup>                          | 55%     |

- 1 Ability of UV to penetrate wastewater and disinfect organisms. Typically determined from wastewater testing, which the CVRD has completed with a vendor previously.

The configuration of the UV system would be two UV disinfection channels as the principle regulations require each UV bank be designed to treat 75% of the design flow with the largest unit out of service, at a minimum. The UV system can be placed outside in concrete channels and does not need to be in a building. However, in the Option 3 and Option 4 assessments, a building should be constructed for the disk filters, and we have assumed some additional floor area in the same building to house the UV system.

Several considerations were given to how the plant might be laid out beyond 2040, and how new infrastructure components can be fit into the existing plant and fit into future plans for the facility. We have given thought to some of these future considerations, in conjunction with the ISL (2016) report's plans, to begin to add some clarity to how the future of the CVWPCC may look. Additionally, a new offline equalization tank is currently being constructed at the CVWPCC to handle peak flows to the treatment plant which was considered during preliminary conceptual layouts. Some other key considerations that we have identified in a potential upgrade are outlined in Table 9.

Table 9: CVWPCC Key Consideration Identification

| KEY CONSIDERATION  | RISK  | POTENTIAL MITIGATION OPTIONS  |
|--|---|---|
| 1. How is new infrastructure integrated with the existing plant? | <p><b>A.</b> By 2040 the existing infrastructure will be 60 years old. Condition assessments may find that some of the assets may be at the end of their useful life and may not be in the plans for future expansions to 2060.</p> <p><b>B.</b> The available head in the hydraulic profile is limited and may limit options to avoid pumping between unit processes. This also makes it difficult to construct a new process tanks away from the existing process tanks and optimize operational efforts.</p> <p><b>C.</b> New equalization tank under construction (shown in layout Figures for Options 2 – 4) reduces the available footprint for a future secondary treatment expansion.</p> | <p><b>A.</b> Ensure new infrastructure can be used beyond 50 years and can be re-used regardless to what happens to the facility plans in 2040.</p> <p><b>B.</b> Try to incorporate flow control options within a layout, or allow for tie-in to future flow control options.</p> <p><b>C.</b> Construct a new headworks to increase the available hydraulic head at the plant, move the primary clarifier to a new location, demolish the existing primary clarifiers and use this space for future secondary treatment expansion.</p> |
| 2. How much longer can the existing infrastructure be used?      | <p><b>A.</b> The generally harsh conditions from H<sub>2</sub>S exposure, can erode concrete and mechanical components in the headworks and primary clarifiers. Re-use of these systems beyond 2040 may be limited and new facilities will likely be required.</p>  | <p><b>A.</b> Condition assessments can be completed on these components that outline faulty or weak components and repairs can be designed to extend the life of the systems. This would be included for aeration basins and secondary clarifiers as well to ensure life beyond 2040.</p> <p><b>B.</b> Locate space on the treatment plant for constructing a new headworks building and primary clarifiers in the future that can still utilize existing aeration basin and secondary clarifier infrastructure.</p>                    |

| KEY CONSIDERATION   | RISK  | POTENTIAL MITIGATION OPTIONS   |
|---|---|--|
| 3. What will the solids handling components look like in the future?                          | <p><b>A.</b> The wastewater treatment plant currently hauls solids to a composting facility for handling. Changes in regulations, cost-benefit analysis, and other factors can drive decisions for solids handling options, such as anaerobic digestion where gas and energy can be recovered.</p> <p><b>B.</b> Age of current solids handling equipment might require refurbishment to ensure the equipment will last until at least 2040.</p> | <p><b>A.</b> Future space considerations for anaerobic digestion should be considered as an option to the CVRD. Digestion could potentially be part of a future overall solids handling system upgrade.</p> <p><b>B.</b> A condition assessment of structural and mechanical components on the thickeners (gravity and DAF units) can provide insight into repairs that may be needed to ensure the life of the equipment will last until at least 2040, as the components do have the capacity.</p> |
| What are the geotechnical conditions of the site and post-disaster structural considerations? | <p><b>A.</b> Building codes and the status of wastewater facilities have changed to be more stringent and require robust facilities in previous years. New infrastructure at wastewater treatment plants now have to be “post-disaster”, which means operable after a natural disaster, such as an earthquake.</p>  | <p><b>A.</b> Complete geotechnical assessments to review the soil conditions of the site.</p> <p><b>B.</b> Complete a structural condition assessment to review the existing infrastructure, expected lifespan, and possible upgrades that may be required to make the infrastructure post-disaster.</p>   |
| What are the odour concerns?  | <p><b>A.</b> New infrastructure should limit increased odours in the area</p>   | <p><b>A.</b> Include allowances for odour connections and odour control measures in new infrastructure. It should be noted we have not reviewed the capacity of the existing odour control system.</p>   |

With these considerations in mind, potential site plans have been developed to meet 2040 flow and load capacity requirements under current regulatory requirements and allow for flexible expansion in the future. A plan developed during a pre-design would confirm or propose alternatives to this plan, the plan proposed by ISL (2016), or an entirely new plan depending on the information and technologies available at the time of pre-design.

In this base case, the following items were identified as items requiring a capacity increase. A detailed condition assessment of some of the structures should be completed to fully assess the suitability of re-using some of the plant’s existing infrastructure.

## PRELIMINARY TREATMENT

- Upgraded grit removal is required and will benefit the plant in several ways, it mostly will improve sludge thickening in the primary clarifiers.
- Rather than re-use the existing screening building and installing new screens and a new grit removal tank, we are proposing to install a new headworks building with new screening and grit removal. The alternative is that a new headworks building in the future will still be required, and the existing screening and grit system would still be maintained. This would mean double the equipment for the preliminary treatment section.



- By constructing a new headworks building now, the hydraulic profile of the plant can be raised so that in the future flow splitting elements (i.e. using weirs) can be used for even flow distribution to the various processes.
- As will be discussed later, there is limited room in the recycled activated sludge (RAS) pumping room and a new clarifier with RAS pump system would be required. A new headworks building would allow room for the RAS pumping system and the primary clarifier sludge pumping system.
- The building would be designed to be post-disaster and last the CVRD a minimum of 75 years.

## **PRIMARY CLARIFIERS**

- Due to secondary treatment space expansion limitations, and the possible poor condition of the primary clarifiers (from their age), we are proposing to re-construct three post-disaster primary clarifiers near the new headworks building to the north, with associated flow splitting.
- A basement section of the new headworks building would provide the primary sludge pumping, and since grit removal is now incorporated, the primary sludge would no longer need to be pumped through grit removal systems at a watered-down sludge concentration. The primary sludge can be thickened in the primary clarifiers and possibly be pumped directly to the sludge storage tanks, rather than to the gravity thickeners. A new sludge storage tank would be incorporated to ensure sufficient storage capacity with increasing solids loading to the plant (refer to the capacity assessment in the Appendix).
- The existing primary clarifiers and grit tanks would be demolished and the space would be used for secondary treatment expansion.

## **AERATION BASINS**

- There is not enough capacity in the existing three aeration basins to handle 2040 loads and a fourth aeration basin is required (refer to the Appendix for the capacity assessment). Due to the space constraints on the site with where the current equalization tank is being installed, new aeration basins are proposed where the existing primary clarifiers are currently located.
- Installing the aeration basins in this location, and adjacent to the existing aeration basins would allow for simple inclusion of the existing aeration piping and blowers to the tank and flow control between the aeration basins.
- This configuration would allow for expansion of future aeration basins to the west for additional process capacity beyond 2040.
- We have assumed that the existing blower room can be re-used and that there is sufficient blower capacity in the existing system (refer to capacity assessment). Although installing new, higher efficiency blowers, may be desired and would be evaluated in a pre-design.

## **SECONDARY CLARIFIERS**

- A fourth secondary clarifier is required and would be installed to the north of the existing clarifiers.
- A new flow splitting box should be installed to ensure equal flow to the four clarifiers, if determined feasible during a pre-design.
- The RAS pumping system would be installed in the new headworks building, future space would also be left in this location for future RAS systems.

## **UV SYSTEM**

- A new UV disinfection system would be installed outdoors with the design criteria outlined in Table 8. The system is assumed to be a Trojan UV Signa system with 96 UV lamps.

The items identified are believed to make-up a possible upgrade scenario for the CVWPCC to meet treatment objectives until 2040, and provide flexibility for expansion beyond 2040. We note that this plan does deviate from the ISL (2016) plan, however this approach will provide a range of costs for two potential options for the CVWPCC to meet 2040 flows and loads (WSP Option 2 versus ISL Options). Investigating the feasibility of these options, together with different treatment technologies, and completing a condition assessment of the existing infrastructure, should be completed during a Master Plan or Pre-Design for the CVRD to confirm the recommended approach.

The approach presented represents a starting point for comparing costs of the desired wastewater treatment levels. For the purposes of this memorandum, this base case is consistent across all three options evaluated in Stage 2 (Option 2, 3, and 4), so that the incremental increase for advanced treatment can be shown.

A potential layout for the above described components is depicted in Figure 1. It is important to note that this conceptual layout, while accounting for as many constraints as possible, a Pre-Design study for the concept will be required to identify any unforeseen constraints not identified here.

## COST ESTIMATE

Preliminary planning capital cost estimates for Option 2 are based on the layout in Figure 1 to upgrade the treatment plant to handle the 2040 design flows and loads. This estimate is based on the assumptions stated previously and provides a general outline for the work that may be required. A detailed Pre-design study with treatment process modelling may provide alternate solutions to reduce costs.

The annual O&M costs are considered *additional* cost to the O&M costs that the plant already incurs. The following assumptions were used in determining additional O&M costs for the new headworks building, primary clarifier, aeration basin, secondary clarifier, and UV system.

- Headworks building: Additional power for vortex grit mixer and associated maintenance costs, assumed to be 1% of the capital costs. Additional HVAC and power costs assumed to be 1 GJ/m<sup>2</sup>/year for the building based on Natural Resources Canada energy intensity for industrial buildings (0.85 GJ/m<sup>2</sup>), with a safety factor.
- Aeration Tank: Diffusers are assumed to be replaced every 10 years. Additional blower power for the extra aeration tank assumed to be 25% of total airflow required under average conditions (additional 20 kW of power).
- Secondary clarifier: Equipment maintenance costs are assumed to be 1% of the equipment capital costs (low maintenance items). It also includes additional power for the rake mechanism and extra RAS pump.
- UV System: Assumes an annual bulb replacement cost of \$850/bulb and power draw at average flow conditions. These numbers are provided by a UV supplier, quotation is provided in the Appendix.
- Power cost is assumed as \$0.12/kWh
- A 5% discount rate and 20-year payment is used to determine the present value of the O&M Costs.
- We have included 15% General Requirements for the Contractor's overhead, mark-up, and miscellaneous costs associated with Construction on the capital cost. We have also included a 10% Fee for the Contractor's profit.
- A 15% engineering and 30% contingency cost are added to the capital cost.
- We have assumed ground improvements are not required on the site to meet post-disaster requirements.
- Electrical costs are assumed to be 25% of the total project costs. However, additional electrical upgrades may be required after a more detailed investigation with respect to the on-site generator, power feed into the treatment plant, and control systems.
- Detailed odour control estimates are not included, we have assumed that the existing odour control system would be satisfactory for the new infrastructure.



The estimated costs for Option 2 are shown in Table 10.

*Table 10: Option 2 Cost Summary*

| <b>OPTION 2 – SECONDARY TREATMENT FOR<br/>ENTIRE FLOW WITH DISINFECTION</b> | <b>AMOUNT</b>        |
|---|----------------------|
| Headworks Building (Screening & Grit)                                       | \$ 6,309,000         |
| Primary Clarifiers  | \$ 5,065,000         |
| New Activated Sludge Aeration Basin   | \$ 3,307,000         |
| New Secondary Clarifier & RAS/WAS System                                    | \$ 3,347,000         |
| UV System   | \$ 1,804,000         |
| <b>Subtotal Base Case Capital Cost</b>                                      | <b>\$ 19,832,000</b> |
| Engineering (15%)   | \$ 2,975,000         |
| Contingency (30%)   | \$ 6,842,000         |
| <b>Total Base Case</b>  | <b>\$ 29,649,000</b> |
| Estimated Annual Additional O&M   | \$ 188,000           |
| PV Annual O&M (20 years, 5% Discount Rate)                                  | \$ 2,384,000         |
| <b>Total Net Present Value Base Case</b>                                    | <b>\$ 32,033,000</b> |

Plot Date: 24 Oct 2019 @ 9:57 AM Path: \MCMOX VALLEY REGIONAL DISTRICT\18P-20276-00\Figure 01.dwg 01 PLOT SCALE: 1:11 PLOTTED BY: Karam, Erin LAST SAVED BY: CAE0064200




Figure 1: Option 2 Site Layout



## OPTION 3 – ADDITION OF ADVANCED TREATMENT FOR 2XADWF

Option 3 evaluates the inclusion of disk filters for advanced treatment to produce a higher quality effluent, i.e. less than 10 mg/L TSS and BOD<sub>5</sub>, for 2xADWF (assumed to be used will utilize an “outside-in” flow pattern where the particulates are kept on the outside of the filters 35,000 m<sup>3</sup>/d). It is anticipated in this scenario a type of flow control weir would be installed to divert higher flows exiting secondary treatment around the disk filters and directly to UV disinfection. Disk filters, or cloth media filters, are disks covered in a cloth material that are placed in a channel where the wastewater meets the filters. The filters and the wastewater continues through the filters and to the outfall. A rendering from a disk filter proposal we received is shown in Figure 2.



*Figure 2: Disk Filter Rendering (from Nexom Proposal in Appendix)*

The disk filters were sized for the 35,000 m<sup>3</sup>/d with an influent TSS concentration of 25 mg/L. Each unit is sized to treat 8,750 m<sup>3</sup>/d. Four disk filter units are proposed to handle the 2040 flows, which provides 75% redundancy. The disk filters are recommended to be placed inside a building. Based on the size of the disk filters required to handle flows up to 2 x ADWF, we have used a building size of 20 by 15 meters. The building was sized to include the UV system, since the UV system has a generally small footprint and inclusion of the UV system indoors would have many benefits at a minimal cost.

This option includes the same items and constraints that were identified under Option 2. A site plan for this option is shown in Figure 3.

## COST ESTIMATE

The cost estimate is shown in Table 11 for Option 3. Included in this cost estimate are the base case estimates described in Option 2 and inclusion of advanced treatment with disk filters. A benefit of the disk filter system is the higher quality water that is then sent for UV disinfection. With the higher quality wastewater, i.e. fewer solids, the UV system can be downsized. With disk filters there is a higher UV Transmittance (UVT) and thus less light bulbs are required in the UV system. In this scenario it is assumed that the Trojan Signa system would have 64 lamps, a UV transmittance of 60%, and TSS of 15 mg/L in the blended effluent.

The same assumptions as outlined in Option 2 are carried in the capital and O&M costs estimates shown in Table 11.




Table 11: Option 3 Cost Summary

**OPTION 3 – ADVANCED TREATMENT FOR  
2XADWF**

**ESTIMATE**

|  |                      |
|--|----------------------|
| Headworks Building (Screening & Grit)      | \$ 6,309,000         |
| Primary Clarifiers                         | \$ 5,065,000         |
| New Activated Sludge Aeration Basin        | \$ 3,307,000         |
| New Secondary Clarifier & RAS/WAS System   | \$ 3,347,000         |
| UV System                                  | \$ 1,627,000         |
| Disk Filters for 2XADWF                    | \$ 5,735,000         |
| <b>Subtotal Option 3 Cost Estimate</b>     | <b>\$ 25,390,000</b> |
| Engineering (15%)                          | \$ 3,809,000         |
| Contingency (30%)                          | \$ 8,760,000         |
| <b>Total Option 3 Cost Estimate</b>        | <b>\$ 37,959,000</b> |
| Estimated Annual O&M Addition              | \$ 202,000           |
| PV Annual O&M (20 years, 5% Discount Rate) | \$ 2,561,000         |
| <b>Total Net Present Value Option 3</b>    | <b>\$ 40,520,000</b> |

Plot Date: 24 Oct 2019 @ 9:57 AM Path: \MCOMOX VALLEY REGIONAL DISTRICT\19P-20276-00\Figure 01.dwg 01 PLOT SCALE: 1:11 LAST SAVED BY: CAEK064200





## OPTION 4 – ADDITION OF ADVANCED TREATMENT FOR ENTIRE FLOW

Option 4 is the same evaluation as Option 3, except the disk filters are sized for the entirety of the flow (62,000 m<sup>3</sup>/d). This disk filter system is assumed to include eight disk filters, each sized for 8,750 m<sup>3</sup>/d, providing a redundant unit. The larger disk filter footprint would require a building approximately 20 by 20 meters and would also include the UV system. The UV system in this scenario would be the smallest since the entire flow is treated to a higher standard and provide the highest quality. In this scenario, the UV system is assumed to be a Trojan Signa with 60% UVT and an influent TSS of 10 mg/L. This system would require a total of 56 UV lamps. The site plan for Option 4 is shown in Figure 4. This includes the same assumptions and layouts from Option 2 as well.

## COST ESTIMATE

The cost estimate for the large disk filters is shown in Table 12. The same assumptions for capital and O&M costs from Option 2 are included in this estimate.

*Table 12: Option 4 Cost Summary*

| OPTION 4 – ADVANCED TREATMENT FOR ENTIRE FLOW | ESTIMATE             |
|---|----------------------|
| Headworks Building (Screening & Grit)         | \$ 6,309,000         |
| Primary Clarifiers                            | \$ 5,065,000         |
| New Activated Sludge Aeration Basin           | \$ 3,307,000         |
| New Secondary Clarifier & RAS/WAS System      | \$ 3,347,000         |
| UV System                                     | \$ 1,311,000         |
| Disk Filters for All Flow                     | \$ 7,602,000         |
| <b>Subtotal Option 4 Cost Estimate</b>        | <b>\$ 26,941,000</b> |
| Engineering (15%)                             | \$ 4,041,000         |
| Contingency (30%)                             | \$ 9,295,000         |
| <b>Total Option 4 Cost Estimate</b>           | <b>\$ 40,277,000</b> |
| Estimated Annual O&M Addition                 | \$ 213,000           |
| PV Annual O&M (20 years, 5% Discount Rate)    | \$ 2,699,000         |
| <b>Total Net Present Value Option 3</b>       | <b>\$ 42,976,000</b> |



Plot Date: 24 Oct 2019 @ 9:57 AM Path: \MCOMOX VALLEY REGIONAL DISTRICT\18P-20276-00\Figure 01.dwg 01 PLOT SCALE: 1:11 LAST SAVED BY: CAEK064200




Figure 3: Option 4 Site Layout

## OPTION 5 – RECLAIMED WATER FOR IN-PLANT USE

Option 5 evaluated including reclaimed water around the CVWPCC for equipment wash water and other reuse items. Reclaimed water standards are set-out in the provincial regulation (MWR) and are classified by exposure potential to the public. Reclaimed water use within the treatment plant would need to meet the lowest exposure potential standards as the reclaimed water would be controlled in the plant setting.

The MWR requires, for low exposure potential, a maximum TSS and BOD<sub>5</sub> concentration of 45 mg/L, a disinfection to 200 MPN/100 mL, and maintaining a pH between 6.5 and 9. Additionally, the MWR requires the reclaimed water to be chlorinated to have a minimum of 0.5 mg/L chlorine residual in the reclaimed water at the point of use.

We have designed several reclaimed water systems for wastewater treatment plants in British Columbia. We have assumed a similar sized system would be installed at the CVWPCC. This system would include a pressure filter to remove TSS and a chlorination system to maintain a residual of 0.5 mg/L total chlorine. There would be a reclaimed water distribution pumping and piping network installed around the plant to service the various mechanical equipment, or onsite irrigation as maybe desirable.

The design criteria for the reclaimed water system is shown in Table 13.

*Table 13: Reclaimed Water Design Criteria*

### CRITERIA

|  |                                   |
|--|-----------------------------------|
| Capacity                                 | 50 m <sup>3</sup> /d              |
| Pressure Filter Capacity (L/min)         | 100                               |
| Chlorine Dosing System Capacity (mL/min) | 10 – 110                          |
| Distribution Pump Capacity (L/s)         | 5                                 |
| Reclaimed Water Clearwell Tank (m3)      | 100 – 150                         |
| Chlorination Dosing                      | 12% Sodium Hypochlorite @ 15 mg/L |

A detailed investigation into the wash water requirements for the reclaimed water system was not included in the scope of work. However, our experience with using this sized system at other wastewater treatment plants indicate sufficient capacity to service most equipment around a wastewater treatment plant. We also have sodium hypochlorite cost estimates for approximately \$1,000 per 1,100L tote, and have assumed approximately 1 tote every 3 months would be required. A cost estimate for Option 5 is shown in Table 14.

*Table 14: Option 5 Cost Summary*

| OPTION 5 - RECLAIMED WATER             | AMOUNT            |
|--|-------------------|
| Civil Works                            | \$ 24,000         |
| Process Mechanical                     | \$ 130,000        |
| Structural Components                  | \$ 180,000        |
| Plumbing & HVAC                        | \$ 8,000          |
| Electrical                             | \$ 68,000         |
| General Requirements                   | \$ 109,000        |
| <b>Subtotal Option 5 Cost Estimate</b> | <b>\$ 519,000</b> |

|  |                   |
|--|-------------------|
| Engineering (15%)                          | \$ 78,000         |
| Contingency (30%)                          | \$ 179,000        |
| <b>Total Option 5 Cost Estimate</b>        | <b>\$ 776,000</b> |
| Estimated Annual O&M Addition              | \$ 6,900          |
| PV Annual O&M (20 years, 5% Discount Rate) | \$ 88,000         |
| <b>Total Net Present Value Option 5</b>    | <b>\$ 864,000</b> |

The cost estimate shown in Table 14 would be for a system treating Option 2 secondary effluent to reclaimed water standards. If disk filters are included and provide a higher quality effluent (Option 3 and 4), the reclaimed water system overall cost could potentially be reduced by approximately \$100,000 - \$150,000.

A small footprint for the reclaimed water system and tank is shown on all three layouts in Options 2 to 4.

## COST ESTIMATE COMPARISON

The capital cost summary from the ISL (2016) report is summarized Table 15. The ISL (2016) report stages the work, therefore we have taken the Phase I (year 2017), Phase II (year 2024), and Phase III (year 2033/2034) cost estimates as they are the most comparable to the base case costs developed in this assessment. The cost numbers have been adjusted in the ISL (2016) report to be in 2019 Canadian dollars using the Engineer News-Record (ENR) indexing values. Note that the costs are taken from the recommended 'Option 3' in the ISL report. Additionally, we want to note that the ISL option includes disk filters for the full flow for initial removal of solids before a new secondary clarifier is installed, therefore we have removed the disk filter estimate component and provided it as a separate item, although in the ISL (2016) staging plan the disk filters would be required before the secondary clarifier is installed. Note that the ISL (2016) estimate does not include UV treatment which is included in all options developed in this assessment.

The estimates prepared in this assessment represent a total amount that would be required to meet 2040 treatment objectives, we have not phased the work as this would typically be completed during a pre-design or master plan. We have compared the ISL (2016) estimates with our estimates in Table 16, since they are relatively different plans going forward to achieve the same treatment objectives for 2040. The ISL (2019 adjusted) estimate not including disk filters (\$27.6M) would be comparable to Option 2 in this assessment and the ISL (2019 adjusted) estimate to include disk filters (\$38.4M) would be comparable to Option 4 in this assessment, including disk filters to treat the entirety of the flow.

We note that the ISL (2016) estimate included more detail beyond 2040, therefore the total life cycle cost estimates for only the items selected to meet 2040 expansion could not be determined and compared to the WSP estimate. However, we would expect them to be similar.

The capital cost range (\$27.6M - \$29.6M) shown in Table 16 for the ISL (2019 adjusted) and Option 2 in this assessment estimate likely represents a total cost for the CVRD to expand the plant to handle 2040 flows and loads. We do note the estimates in this assessment include a 5% greater (45% vs 40%) engineering and contingencies amount than the ISL (2016) estimate. The actual path forward, and staging of the expansion, would be determined during a Pre-Design step.

Table 15: ISL (2016) Report - Option 3 Cost Estimate Comparison

| STAGE                             | ISL ESTIMATE 2016<br>CDN\$                     | ISL ESTIMATE 2019<br>CDN\$ <sup>1</sup> | ISL ESTIMATE<br>2016 CDN\$                 | ISL ESTIMATE<br>2019 CDN\$ <sup>1</sup> |
|-----------------------------------|--|---|--|---|
|                                   | <b>ISL Option 3 Not Including Disk Filters</b> |   | <b>ISL Option 3 Including Disk Filters</b> |   |
| Phase I (2017)                    | \$ 5,774,000 <sup>2</sup>                      | \$ 6,289,000                            | \$ 11,063,000 <sup>2</sup>                 | \$ 12,050,000                           |
| Phase II (2024)                   | \$ 4,721,000 <sup>3</sup>                      | \$ 5,142,000                            | \$ 4,721,000 <sup>3</sup>                  | \$ 5,142,000                            |
| Phase III (2033/2034)             | \$ 7,651,000 <sup>4</sup>                      | \$ 8,333,000                            | \$ 9,410,000 <sup>5</sup>                  | \$ 10,249,000                           |
| Engineering & Contingencies (40%) | \$ 7,258,400                                   | \$ 7,906,000                            | \$ 10,077,600                              | \$ 10,976,000                           |
| Total Capital Cost Estimate       | \$ 25,404,400                                  | \$ 27,670,000                           | \$ 35,271,600                              | \$ 38,417,000                           |

1 ENR Index Values used for 2016: 10,339 and ENR Index Values used for 2019: 11,261

2 From ISL (2016) Table 12.1 for Option 3 – with and without disk filters line item.

3 From ISL (2016) Table 12.2 for Option 3

4 From ISL (2016) Table 12.3 for Option 3 Primary Clarifiers + Process Building – Year (2033) Line Item

5 From ISL (2016) Table 12.3 for Option 3 Primary Clarifiers + Process Building – Year (2033) Line Item and Upgrade Media Cloth Filter – Year (2034) Line Items.

Table 16: Capital Cost Comparison

|                                  | ISL (2019)<br>ESTIMATE                | OPTION 2   | OPTION 3   | OPTION 4  | ISL (2019)<br>ESTIMATE            |
|----------------------------------|---------------------------------------|--|--|---|-----------------------------------|
|                                  | <b>Not Including<br/>Disk Filters</b> | <b>Secondary<br/>Treatment for<br/>Entire flow w/<br/>Disinfection</b> | <b>Addition of<br/>Advanced<br/>Treatment for<br/>2XADWF</b> | <b>Addition of<br/>Advanced<br/>Treatment for<br/>Entire Flow</b> | <b>Including Disk<br/>Filters</b> |
| Total Capital Cost Estimate      | \$ 27,670,000                         | \$29,700,000   | \$ 38,000,000  | \$ 40,300,000   | \$ 38,417,000                     |
| 20 Year Life Cycle Cost Estimate | \$ -                                  | \$32,000,000   | \$ 40,500,000  | \$ 43,000,000   | \$ -                              |



## SUMMARY

A summary of the cost estimates for the different treatment level options is shown in Table 17. We note that due to the relatively similar amounts between ISL (2019) and the estimates in this assessment, the estimates developed in this assessment will be used for comparison purposes.

This estimate also includes the estimate from the ISL (2016) *Cape Lazo Outfall Capacity Assessment* for ‘Option 3’ of approximately \$24.4M which is carried to indicate future capital upgrade requirements for the outfall. Also note that Option 5 is only for including reclaimed water, and does not represent a standalone option for the District in terms of upgrading the secondary treatment capacity.

Upgrades to meet federal and provincial requirement by implementing secondary treatment upgrades are effective in protecting the receiving environment, removing microplastics and disinfecting the effluent prior to release in the receiving environment.

Currently, advanced treatment is not a regulatory requirement for an ocean discharge, and advanced treatment is not strictly required to meet the regulatory treatment objectives for the CVWPCC with appropriate expansion of the existing systems. To provide advanced treatment for the entire flow with disk filters, it is currently estimated as a 35% to 40% increase in capital costs (~\$11M). To provide advanced treatment for 2xADWF with disk filters, it is estimated as an approximate 25% to 30% increase in capital costs (~\$8M).

The added benefit of disk filters includes treating the effluent to a slightly higher standard, enhanced removal of microplastics, and additional removal of other contaminants associated with the solids in the effluent. If phosphorus removal becomes a regulatory requirement in the future, they would provide additional filtration to reduce phosphorus concentrations following chemical coagulation. Additionally, implementation of disk filters would make the effluent meet standards for reclaimed water, enabling a wide range of uses. However, in the absence of a user for large scale reclaimed water, the estimated 35% increase in capital cost between Options 2 and 3 or 4 may not justify installation of disk filters for advanced treatment at this point in time.

A summary of the costs, risks and benefits of the different options is shown in Table 17.





Table 17: Summary of Wastewater Treatment Level Options

|   | OPTION 2  | OPTION 3  | OPTION 4   |
|---|---|---|--|
|   | Secondary Treatment w/<br>Disinfection Base Case  | Advanced Treatment for<br>2xADWF  | Advanced Treatment for Entire<br>Flow  |
| Sub-Total<br>CVWPCC<br>Upgrade<br>Capital Costs | \$ 29,700,000   | \$ 38,000,000   | \$ 40,300,000  |
| Sub-Total<br>Outfall<br>Upgrades <sup>1</sup>   | \$24,400,000  |   |  |
| <b>Total</b>                                    | <b>\$ 54,100,000</b>  | <b>\$ 62,400,000</b>  | <b>\$ 64,700,000</b>   |
| Subtotal<br>Reclaimed<br>Water (Option<br>5)    | \$800,000   |   |  |
| <b>Total</b>                                    | <b>\$ 54,900,000</b>  | <b>\$ 63,200,000</b>  | <b>\$ 65,500,000</b>   |
|   |   |   |  |
| <b>Benefits</b>                                 | <ul style="list-style-type: none"> <li>— Upgrade path to meet capacity and regulatory requirements for the next 20 years</li> <li>— Secondary treatment removes 90% of organic material and solids on average</li> <li>— Secondary treatment removes 80-95% of microplastics on average</li> <li>— Disinfection to meet shellfish standards</li> <li>— Reclaimed water can be incorporated.</li> <li>— Design can incorporate space for installation disk filters if required in the future.</li> </ul> | <ul style="list-style-type: none"> <li>— Base case secondary treatment upgrades apply</li> <li>— Treating for 2xADWF accounts for approximately 99% of the annual flow being treated</li> <li>— Addition of advanced treatment filtration removes 96% of organic material and solids on average, a marginal increase of 6% over secondary treatment</li> <li>— Addition of disk filters removes 95-97% of microplastics on average, a marginal increase of 15-17% over secondary treatment</li> <li>— Large scale effluent reuse can be implemented</li> <li>— Disk filters can be implemented in the future once a user for reclaimed water is identified</li> </ul> | <ul style="list-style-type: none"> <li>— Base case secondary treatment upgrades apply</li> <li>— Addition of disk filters removes 96% of organic material and solids on average, a marginal increase of 6% over secondary treatment</li> <li>— Addition of advanced treatment filtration removes 95-97% of microplastics on average, a marginal increase of 15-17% over secondary treatment</li> <li>— Large scale effluent reuse can be implemented</li> <li>— Disk filters can be implemented in the future once a user for reclaimed water is identified</li> </ul> |

|              |  |   |   |
|--------------|--|---|---|
| <b>Risks</b> | <ul style="list-style-type: none"> <li>Capital costs are dependent on condition assessment and outcome of a Pre-design study.</li> </ul> | <ul style="list-style-type: none"> <li>Cost premium of approximately \$8M for addition of disk filters to treat 2xADWF</li> <li>Advanced treatment to the level provided by disk filters is not a regulatory requirement</li> <li>Without a user for the reclaimed water, costs may not be justified at this point in time</li> </ul> | <ul style="list-style-type: none"> <li>Cost premium of approximately \$10.7M for addition of disk filters to treat the full flow</li> <li>Advanced treatment to the level provided by disk filters is not a regulatory requirement</li> <li>Without a user for the reclaimed water, costs may not be justified at this point in time</li> </ul> |
|--------------|--|---|---|

1 From ISL (2016) Cape Lazo Outfall Capacity Assessment, to be updated.

2 Cost estimates are in \$2019 CAD. Estimates are appropriate for the purposes of comparing options.

A detailed Pre-design and Condition Assessment for the wastewater treatment plant is recommended. The purpose of these studies would be to:

- Detail the suitability of reusing existing infrastructure and identify any repairs that should be carried out before re-using;
- Create a process model for the treatment plant to identify if there are any modifications that can be done to the existing system to increase performance and capacity;
- Evaluate existing structures and geotechnical conditions that consider post-disaster seismic standards currently required by the B.C. Building Code (BCBC);
- Evaluate plant wide odour control systems and necessary upgrades;
- Complete a pre-design study that provides a detailed, staged expansion plan for the CVWPCC for the next 50 years and beyond;
- Undertake a complete hydraulic assessment of the plant systems;
- Review the plant electrical, controls, and SCADA systems;
- Complete detailed composite sampling to confirm loading in the influent and primary effluent.

A staged approach to upgrading the treatment plant would provide the greatest flexibility and assurance to the CVRD that the appropriate measures have been taken for the decisions that will be made about the future of the plant. The staging would involve completing a condition assessment first to assess the possibility of re-using certain assets and identifying their anticipated life expectancy. After this, a Pre-design Study can be completed knowing the specific condition of assets and creating a process model to identify and evaluate upgrade options so that the best upgrade path and site layout is selected. A preliminary cost estimate to complete these two studies is shown in Table 18.

*Table 18: Pre-design and Condition Assessment Estimates*

| ITEM                       | ESTIMATE  |
|----------------------------|-----------|
| CVWPCC Master Plan         | \$150,000 |
| Asset Condition Assessment | \$150,000 |

We note that repairs to assets are not included in the estimate, nor is the engineering design for the repairs. The scope of work that would be required would be identified in the condition assessment report and an estimate of the repairs required would be provided then.



A possible timeline for completing plant upgrades for the 2040 horizon is shown in Figure 5. This estimated timeline would provide an upgraded facility for the CVRD by 2024 or 2025, and this timeline would be updated in a Pre-Design Study to confirm whether any upgrades need to be accelerated or can be delayed.




Figure 5: Project Timeline





## APPENDIX

## MEMO

**TO:** Kris La Rose, P.Eng., CVRD, Zoe Berkey, EIT, CVRD, Paul Nash  
**FROM:** Tyler Barber, P.Eng., Aline Bennett, P.Eng., Al Gibb, P.Eng.  
**SUBJECT:** CVRD LWMP – Existing System Capacity Assessments (Appendix)  
**DATE:** November 26, 2019

---

## INTRODUCTION

The Comox Valley Regional District (CVRD) has retained WSP Canada Group Ltd. to complete the Liquid Waste Management Plan (LWMP) for the District. As part of the work, WSP will complete the Stage 2 wastewater treatment assessment for the Comox Valley Water Pollution Control Centre (CVWPCC). To assist this work, this memo reviews, at a high-level, the estimated process capacity of the existing infrastructure at the CVWPCC and what is required for expansion to handle 2040 flows and loads into the CVWPCC, while considering implications for future expansion beyond 2040.

This memo describes the findings of this assessment and provides the following information:

- Updated flow and load information;
- High-level review of the capacity of each unit process;

The intent of this assessment is to provide a summary of the process units that require expansion at the CVWPCC. A base case can then be developed with a cost estimate for the minimum requirement of expansion to meet 2040 flows and loads. A large input to this memorandum is the *CVWPCC Capacity Assessment* completed by ISL Engineering and Land Services in 2016, which details operation of the plant and the existing system components.

## POPULATION, FLOW AND LOAD PROJECTIONS

### CVWPCC POPULATION PROJECTIONS

Population for the CVWPCC service area is projected based on expected growth rates for the area. Current service areas to the CVWPCC include the City of Courtenay, the Town of Comox, CFB Comox and K'ómoks First Nation (KFN). Historical population for the City of Courtenay and the Town of Comox (includes KFN) was obtained from the BC Stats database. According to the 2016 ISL *CVWPCC Capacity Assessment* report, future connections to the CVWPCC service area include 400 single-family units referred to as the CVRD Annexation, this is also included in the population assessment shown in Table 1. Service area growth is projected using the annual growth rates used by ISL in their 2016 *CVWPCC Capacity Assessment*. Table 1 shows the historical and projected populations for the service area.

Table 1: Historical and Projected Population to Year 2060

| YEAR                     | CITY OF<br>COURTENAY <sup>(1)</sup> | TOWN OF<br>COMOX <sup>(2)</sup> | CFB<br>COMOX | CVRD<br>ANNEXATION <sup>(3)</sup> | K'OMO<br>KS FN <sup>4</sup> | TOTAL  |
|--------------------------|-------------------------------------|---------------------------------|--------------|-----------------------------------|-----------------------------|--------|
| <b>2013</b>              | 24,815                              | 13,933                          | 966          | -                                 |                             | 39,714 |
| <b>2014</b>              | 25,187                              | 14,216                          | 966          | -                                 |                             | 40,369 |
| <b>2015</b>              | 25,782                              | 14,518                          | 966          | -                                 |                             | 41,266 |
| <b>2016</b>              | 26,736                              | 14,652                          | 966          | -                                 |                             | 42,354 |
| <b>2017</b>              | 27,146                              | 14,850                          | 966          | -                                 |                             | 42,962 |
| <b>2018</b>              | 27,533                              | 14,706                          | 966          | -                                 | 293                         | 43,498 |
| <b>2019</b>              | 28,117                              | 14,994                          | 966          | -                                 | 293                         | 44,370 |
| <b>Future Population</b> |                                     |                                 |              |                                   |                             |        |
| <b>2020</b>              | 28,713                              | 15,281                          | 966          |                                   | 299                         | 45,259 |
| <b>2030</b>              | 33,053                              | 17,558                          | 966          | 1,098                             | 343                         | 53,018 |
| <b>2040</b>              | 37,759                              | 20,057                          | 966          | 1,274                             | 392                         | 60,448 |
| <b>2050</b>              | 43,135                              | 22,913                          | 966          | 1,478                             | 448                         | 68,940 |
| <b>2060</b>              | 49,277                              | 26,176                          | 966          | 1,716                             | 511                         | 78,645 |

<sup>1</sup>2020 – 2021 growth rate of 2.12% and 2022 – Future growth rate of 1.34% from ISL 2016

<sup>2</sup>2020 – 2021 growth rate of 1.92% and 2022 – Future growth rate of 1.34% from ISL 2016

<sup>3</sup>2020 – Future growth rate of 1.5% used from ISL 2016

## FLOW PROJECTIONS

The 2013 to 2017 flow rates provided in Table 2 were used to generate average per capita flow rates into the CVWPCC. These were applied to future year population projections to determine future flow rates to year 2060. The flow rates were determined as follows:

- Average Dry Weather Flow (ADWF): Minimum 30-day rolling average flow for the year;
- Average Daily Flow (ADF): Average flow during the year;
- Average Wet Weather Flow (AWWF): Maximum 30-day rolling average flow for the year;
- Max day flow (MDF): Maximum single day flow in the year;
- Peak Hourly Flow (PHF): Peaking factor developed by ISL (2016) was used to determine projected PHF (3.0 x ADF); and
- Maximum Instantaneous Flow: Peaking factor developed by ISL (2016) was used to determine projected maximum instantaneous flow (3.2 x ADF).

*Table 2: Historical Flows, 2013-2017*

| Year    | Population | HISTORICAL FLOWS <sup>(1)</sup> , M <sup>3</sup> /DAY |        |        |        | UNIT FLOWS, L/C/D |     |      |     |
|---------|------------|---|--------|--------|--------|-------------------|-----|------|-----|
|         |            | ADWF  | ADF    | AWWF   | MDF    | ADWF              | ADF | AWWF | MDF |
| 2013    | 39,714     | 12,142  | 13,249 | 15,029 | 21,225 | 306               | 334 | 378  | 534 |
| 2014    | 40,369     | 11,906  | 14,221 | 20,000 | 38,462 | 295               | 352 | 495  | 953 |
| 2015    | 41,266     | 11,504  | 13,732 | 21,914 | 37,253 | 279               | 333 | 531  | 903 |
| 2016    | 42,354     | 11,518  | 15,462 | 23,533 | 39,998 | 272               | 365 | 556  | 944 |
| 2017    | 42,962     | 11,694  | 14,328 | 19,650 | 34,965 | 272               | 334 | 457  | 814 |
| Average |            |   |        |        |        | 285               | 343 | 484  | 830 |

(1) From Daily Influent Plant Data.

With the data available to WSP at the time of completing this memo, PHF and maximum instantaneous flow were not able to be determined with the data, therefore the peaking factors from ISL (2016) were used. Table 3 shows these projected future flows from 2020 to 2060. These flow projections use the same per capita flows determined in Table 2.

*Table 3: Flow Projections, 2020-2060*

|   | 2020   | 2030   | 2040   | 2050   | 2060   |
|---|--------|--------|--------|--------|--------|
| <b>Population Projection</b>                | 45,259 | 53,018 | 60,448 | 68,940 | 78,645 |
| <b>Flow Projections</b>                     |        |        |        |        |        |
| Average Dry Weather Flow (ADWF) (m3/d)      | 12,885 | 15,094 | 17,210 | 19,627 | 22,390 |
| Average Day Flow (ADF) (m3/d)               | 15,542 | 18,206 | 20,758 | 23,674 | 27,007 |
| Average Wet Weather Flow (AWWF) (m3/d)      | 21,887 | 25,640 | 29,233 | 33,339 | 38,033 |
| Max Day Flow (MDF) (m3/d)                   | 37,547 | 43,984 | 50,148 | 57,193 | 65,244 |
| Peak Hour Flow <sup>(1)</sup> (PHF) (m3/d)  | 46,626 | 54,619 | 62,274 | 71,022 | 81,020 |
| Maximum Instantaneous <sup>(2)</sup> (m3/d) | 49,734 | 58,260 | 66,425 | 75,757 | 86,421 |
| Maximum Instantaneous (L/s)                 | 576    | 674    | 769    | 877    | 1,000  |

(1) Peaking Factor of 3.0 was adapted from the ISL CVWPCC Capacity Assessment (2016).

(2) Peaking Factor of 3.2 was adapted from the ISL CVWPCC Capacity Assessment (2016).

## LOAD PROJECTIONS

Table 4 summarizes the historical (2013 to 2017) influent 5-day Biochemical Oxygen Demand (BOD<sub>5</sub>) and Total Suspended Solids (TSS) loadings used to develop average per capita unit loading rates. The BOD<sub>5</sub> data is taken from composite samples taken approximately once per week for the time periods indicated. Total Suspended Solids (TSS) samples are assumed to be grab samples that were taken approximately 3 – 4 times per week for the duration of the time periods indicated. Average BOD<sub>5</sub> and TSS loads are found in Table 4.

Table 4: Historical Influent Loading, 2013-2017

| HISTORICAL INFLUENT LOADING <sup>(1)</sup> , KG/D |                           |                          |                            |             |               | INFLUENT UNIT LOADING, G/C/D |                            |             |               |
|---|---------------------------|--------------------------|----------------------------|-------------|---------------|------------------------------|----------------------------|-------------|---------------|
| Year  | Population <sup>(2)</sup> | Average BOD <sub>5</sub> | Max Month BOD <sub>5</sub> | Average TSS | Max Month TSS | Average BOD <sub>5</sub>     | Max Month BOD <sub>5</sub> | Average TSS | Max Month TSS |
| 2013  | 39,714                    | 3,327                    | 4,085                      | 3,425       | 4,383         | 84                           | 103                        | 86          | 110           |
| 2014  | 40,369                    | 3,720                    | 8,983                      | 4,144       | 6,198         | 92                           | 223                        | 103         | 154           |
| 2015  | 41,266                    | 3,675                    | 5,641                      | 3,977       | 5,351         | 89                           | 137                        | 96          | 130           |
| 2016  | 42,354                    | 2,605                    | 6,919                      | 4,412       | 6,988         | 62                           | 163                        | 104         | 165           |
| 2017  | 42,962                    | 2,946                    | 4,306                      | 4,116       | 5,189         | 69                           | 100                        | 96          | 121           |
| Average   |                           |                          |                            |             |               | 79                           | 145                        | 97          | 136           |

(1) Plant Data. We have assumed this data includes all return streams from the plant.

(2) Population was obtained from BC Stats.

The average per capita loading for BOD<sub>5</sub> and TSS were rounded to 80 and 100 g/c/d. These values compare to the ISL (2016) per capita values used of 90 g/c/d and 100 g/c/d for BOD<sub>5</sub> and TSS, respectively. We have assumed that the loads from ISL (2016) and the data WSP analyzed includes the additional loading received from septage and return flows in the plant.

We note that the peaking factor between average and max month BOD<sub>5</sub> per capita loading (1.8) is more than what would be expected for typical domestic wastewater. Therefore, we have removed the 223 g/c/d data point for the year 2014 and are using an average max month per capita loading of 126 g/c/d for BOD<sub>5</sub>. TSS max month loading was found to be 136 g/c/d. This compares with the max month loading from ISL (2016) of 117 g/c/d and 120 g/c/d for BOD<sub>5</sub> and TSS, respectively.

No data was available for Total Kjeldahl Nitrogen (TKN), therefore loading data is based on per capita unit rates from ISL (2016). The TKN loading determined in ISL (2016) was based on 13 g/c/d, which is considered typical for domestic wastewater without any industrial loading. They also determined a peaking factor of 1.1 between average and max month loading. These same values were carried forward for projecting TKN load to the CVWPCC. Table 5 shows the projected future loads to the CVWPCC for BOD<sub>5</sub>, TSS, and TKN.

Table 5: Load Projections, 2020-2060

|                                   | 2020   | 2030   | 2040   | 2050   | 2060   |
|-----------------------------------|--------|--------|--------|--------|--------|
| <b>Population Projection</b>      | 45,259 | 53,018 | 60,448 | 68,940 | 78,645 |
| <b>Load Projections</b>           |        |        |        |        |        |
| <b>BOD<sub>5</sub></b>            |        |        |        |        |        |
| Average BOD <sub>5</sub> (kg/d)   | 3,621  | 4,241  | 4,836  | 5,515  | 6,292  |
| Max month BOD <sub>5</sub> (kg/d) | 5,693  | 6,669  | 7,603  | 8,672  | 9,892  |
| <b>TSS</b>                        |        |        |        |        |        |
| Average TSS (kg/d)                | 4,526  | 5,302  | 6,045  | 6,894  | 7,865  |
| Max month TSS (kg/d)              | 6,155  | 7,210  | 8,221  | 9,376  | 10,696 |
| <b>TKN</b>                        |        |        |        |        |        |
| Average TKN (kg/d)                | 588    | 689    | 786    | 896    | 1,022  |
| Max month TKN (kg/d)              | 647    | 758    | 864    | 986    | 1,125  |

## CVWPCC CAPACITY ASSESSMENT

### EXITING WASTEWATER TREATMENT SYSTEM

The CVWPCC is a secondary level activated sludge plant that was constructed in 1982 and receives flow from five (5) pump stations. The plant has the following treatment processes at the facility:

- Preliminary treatment with two coarse bar screens and three pre-aeration grit removal tanks;
- Three primary clarifiers;
- Three activated sludge aeration basins;
- Three secondary clarifiers;
- Effluent outfall and pump station for peak flows;
- Two gravity thickeners for the primary sludge (PS);
- Two dissolved air flotation (DAF) units for waste activated sludge (WAS) thickening;
- One combined (PS and WAS) thickened sludge storage tank;
- Two centrifuges for dewatering;
- Ancillary process such as odour control and grit classification.

The following sections provide a summary for each of the unit process in the liquid and solids treatment trains and a high-level capacity assessment of the equipment to handle the 2040 design flows and loads.

### PRELIMINARY TREATMENT

The preliminary treatment at the CVWPCC consists of a headworks building with two mechanically raked bar screens located in two channels. The screens are 100% redundant and operate in a duty-standby configuration (ISL 2016).

Screen #1 was part of the original 1982 construction and has 12 mm bar openings in the screen. This spacing is large for newer wastewater treatment plants, and generally screens with 6 mm spacing are installed. Screen #2 (6 mm spacing) was installed in 2010 and replaced a manually raked bar screen in a bypass channel. According to the ISL (2016) report, the operator's have reported poor performance by the 12mm bar screen. There is an overflow weir in the channels to bypass the screens in the event of a peak flow event and significant screen blockage.

The capacity of the existing screening system is depicted in Table 6 (ISL 2016).

*Table 6: Screenings System Capacity*

| DESCRIPTION                        | SCREEN #1                  | SCREEN #2                  |
|------------------------------------|----------------------------|----------------------------|
| Number of Screens                  | 1 (alternate duty/standby) | 1 (alternate duty/standby) |
| Channel Width (m)                  | 1.5                        | 1.5                        |
| Channel Depth (m)                  | 2.33                       | 2.33                       |
| Bar Spacing (mm)                   | 12                         | 6                          |
| Rated Capacity (m <sup>3</sup> /d) | 75,000                     | 75,000                     |

The screening system is designed to handle the maximum instantaneous flow from the various pump stations that pump wastewater into the headworks. The current maximum instantaneous flow peaking factor as determined from ISL (2016) is 3.2 (times average daily flow). Using this peaking factor and the projected flow in Table 3 we can see that 75,000 m<sup>3</sup>/d can service a population up until approximately 2050.

As outlined in the ISL 2016 report, the existing 12 mm mechanically raked bar screen should be upgraded to a 6 mm screen (like was done with Screen #2). The 12 mm screen from the original 1982 design is nearly 40 years old and is likely nearing the end of life as well.

ISL (2016) recommended replacing Screen #1 in the existing headworks channel. We believe this to be feasible; however, we note that the building and screenings channel are nearing 40 years old, and in our experience headworks buildings are exposed to a harsh environment due to high hydrogen sulfide (H<sub>2</sub>S) concentrations. The H<sub>2</sub>S can damage concrete and other structural components in the building. A detailed condition assessment can report on the suitability of the structure to be re-used. Other considerations, involve structural and geotechnical assessments for the existing infrastructure and the ability to meet current applicable building codes. Current codes require that wastewater treatment plants are "post-disaster" and are operable in a disastrous event, such as an earthquake.

Following screening, the wastewater is conveyed via an aerated channel to three pre-aeration grit tanks that are located in-line with the three primary clarifier tanks. Each pre-aeration grit tank is dedicated to the downstream primary clarifier unit it services. The aerated grit tanks provide some grit removal from the influent wastewater, the remaining grit is removed in the primary clarifier

tanks. The pre-aeration grit tanks are covered to provide some odour control. The tanks are 3.7 meters long by 6.1 meters wide and have a depth of 3.6 meters (ISL 2016).

The grit slurry is removed from the pre-aeration grit tanks through two (one duty/one standby) dedicated grit pumps that pump the slurry to two grit classifiers. The grit from the classifiers is conveyed to two storage bins and then transported offsite for disposal. The primary clarifier sludge pump also pumps through a grit classifier to remove grit, before being conveyed to the gravity thickener (ISL 2016).

The pre-aeration grit tank system capacity assessment for grit removal from ISL (2016) is shown in Table 7. The assessment is based on the size of the tanks compared to textbook recommended sizes, as there is no grit data available to evaluate performance.

*Table 7: Pre-Aeration Grit Tank Assessment*

| DESCRIPTION                       | PRE-AERATION GRIT TANKS | RECOMMENDED DESIGN VALUES |
|-----------------------------------|-------------------------|---------------------------|
| No. Units                         | 3                       | -                         |
| Length (m)                        | 3.7                     | -                         |
| Width (m)                         | 6.1                     | -                         |
| Depth (m)                         | 3.6                     | -                         |
| Volume (m <sup>3</sup> )          | 81.3                    | -                         |
| L : W Ratio                       | 0.61 : 1                | 3 – 5 : 1                 |
| 2020 PHF Retention Time (Minutes) | 1.8                     | 2 – 5                     |
| W : D Ratio                       | 1.7                     | 0.8 – 1 : 1               |

The current pre-aeration grit tanks do not meet recommended design values for retention time, length to width ratios, and width to depth ratios. Based on the ISL (2016) assessment and the current configuration of the CVWPCC, it appears the grit removal system is atypical of a sewage treatment plant. The grit removal is accomplished partially through these pre-aeration grit tanks, and partially through the primary clarifiers. However, it is important to note that these two processes appear to achieve thorough grit removal, as the operators do not report any grit in processes downstream of the primary clarifiers.

Grit is harsh on pumps, pipes, diffuser membranes, and various other components within a treatment plant. Since it seems that most of the grit is removed in the first two unit-processes, the main concern would be the effects of grit on the primary sludge pumping. If anaerobic digestion of



waste solids is added in the future, grit accumulation in the digesters from the primary sludge may be a concern.

The ISL (2016) report recommended including a vortex style grit removal system that would be designed to remove 95% of grit down to 140 mesh size (105 microns). This would allow the CVRD to decommission the grit classifier equipment that is used to classify grit in the primary sludge and to decommission or re-purpose the pre-aeration grit tanks ahead of the primary clarifiers. Additionally, as will be discussed in the next section, the addition of a proper grit removal system will allow the primary clarifiers to be operated normally and allow the sludge to thicken in the primary clarifiers and can then bypass the gravity thickeners (currently, the primary sludge is only reported to be 0.1% instead of 3% - 5%) (ISL 2016).

It is important to note that the ISL (2016) report included constructing a grit tank now and in the future (beyond 2040) when a new headworks building would be required with a new grit removal system. It is assumed this is required due to the plants hydraulic profile and the concept was to include two headworks systems (the current existing one and one constructed beyond 2040). Rather than including a grit tank now and delaying a new headworks construction, we have included a new headworks building with screening and grit removal that would be constructed now, and be designed to meet current building codes and for a lifespan of at least 75 years. This would also allow the CVRD to raise the hydraulic profile in the plant so that flow splitting structures can be installed between the different unit processes as the plant expands.

## PRIMARY CLARIFIERS

The CVWPCC is equipped with three primary clarifier tanks from the original construction in 1982. Each tank is directly downstream from its own grit tank, as described in the previous section. Each primary clarifier is 32.65 meters long by 6.1 meters wide by 3.6 meters deep. The 1982 record drawings show that the average water depth in the primary clarifier is approximately 2.8 meters.

According to the 1982 record drawings, space was allocated to the west of the primary clarifiers, and provisions were set-in the original design for expansion of the plant with two additional primary clarifiers. This expansion has not yet occurred.

Sludge is removed from the primary clarifiers by the longitudinal chain and flight clarifier mechanism that scrapes sludge into a hopper at the inlet side of the clarifier tank. From here, the sludge is pumped by two primary sludge pumps (one duty/one standby). There is a common primary clarifier sludge collection header and the branch to each clarifier is fit with a control valve to alternate from which clarifier the sludge is drawn. The primary sludge is pumped by the two primary sludge pumps to a dedicated grit classifier (one duty/one standby) where grit is removed and washed. For the grit classifiers to work properly, the primary sludge needs be less than 0.5% total solids (ISL 2016). ISL (2016) reported that currently the primary sludge is withdrawn from the primary clarifiers at approximately 0.1%, much less than what would typically be seen in primary clarifiers (3% to 5%). De-gritted Primary sludge is then sent by gravity to the gravity sludge thickeners for thickening.

The primary clarifiers were evaluated based on surface overflow rate and detention time based on the updated flows from Table 3. The capacity assessment is shown in Table 8 for all units in service receiving 100% of the flow (column A), two out of three units receiving 100% of the flow (column B), two out of three units receiving 50% of the flow (column C). The MWR requirement

is that the primary clarifiers need to treat 50% of the flow with the largest unit out of service. Note a red value indicates the value is outside of the recommended range (typical for all design tables).

*Table 8: Primary Clarifier Capacity Assessment*

| DESCRIPTION   | A. PRIMARY CLARIFIERS (ALL FLOW) | B. PRIMARY CLARIFIERS (ALL FLOW – ONE UNIT OUT OF SERVICE) | C. PRIMARY CLARIFIERS (50% OF FLOW – ONE UNIT OUT OF SERVICE) | RECOMMENDED VALUES |
|---|----------------------------------|--|---|--------------------|
| No. of units  | 3                                | 2  | 2   | -                  |
| LxWxH (m)   | 32.65 x 6.10 x 2.80              | -  | -   | -                  |
| Surface Area (m <sup>2</sup> )                                      | 597                              | 398  | 398   | -                  |
| Volume (m <sup>3</sup> )  | 1,673                            | 1,115  | 1,115   | -                  |
| 2040 ADF (m <sup>3</sup> /d)  | 20,758                           | 20,758   | 10,379  | -                  |
| 2040 AWWF (m <sup>3</sup> /d)                                       | 29,233                           | 29,233   | 14,617  | -                  |
| 2040 2 x ADWF (m <sup>3</sup> /d)                                   | 34,419                           | 34,419   | 17,210  |                    |
| 2040 PHF (m <sup>3</sup> /d)  | 62,274                           | 62,274   | 31,137  | -                  |
| 2040 ADF Surface Overflow Rate (m <sup>3</sup> /m <sup>2</sup> /d)  | 35                               | 52   | 26  | 30 – 50            |
| 2040 AWWF Surface Overflow Rate (m <sup>3</sup> /m <sup>2</sup> /d) | 49                               | 73   | 37  | 30 – 50            |
| 2040 2 x ADWF Surface Overflow Rate                                 | 58                               | 86   | 43  | 30 – 50            |

| DESCRIPTION  | A. PRIMARY CLARIFIERS (ALL FLOW) | B. PRIMARY CLARIFIERS (ALL FLOW – ONE UNIT OUT OF SERVICE) | C. PRIMARY CLARIFIERS (50% OF FLOW – ONE UNIT OUT OF SERVICE) | RECOMMENDED VALUES |
|--|----------------------------------|--|---|--------------------|
| 2040 PHF Surface Overflow Rate (m <sup>3</sup> /m <sup>2</sup> /d) | 104                              | 156  | 78  | 80 – 120           |
| 2040 ADF Detention Time (hr)                                       | 1.9                              | 1.3  | 2.6   | 1.5 – 2.5          |
| 2040 AWWF Detention Time (hr)                                      | 1.4                              | 0.9  | 1.8   | 1.5 – 2.5          |
| 2040 2 x ADWF Detention Time (hr)                                  | 1.2                              | 0.8  | 1.6   | 1.5 – 2.5          |
| 2040 PHF Detention Time (hr)                                       | 0.6                              | 0.4  | 0.9   | 1.5 – 2.5          |

As can be seen in Table 8, there appears to be capacity in the existing primary clarifiers to reach the 2040 design horizon with all units in service (column A) and to meet the MWR requirement (column C). However, as flows increase, the removal efficiency of solids (and BOD<sub>5</sub>) from primary treatment will also decrease, which will increase solids and organic loads to secondary treatment.

It is important to note that there are currently no mechanisms in place to assure even flow splitting between any of the unit processes (primary clarifiers, aeration basins, and secondary clarifiers). This can hinder performance if issues cause any one process to receive flow unequally. There does not appear to be enough hydraulic head available in the hydraulic profile to add flow splitting weir boxes for the primary clarifiers.

A condition assessment of the existing clarifiers structural condition should also be completed to assess their anticipated lifespan and any repairs that are required. Primary clarifiers can also have high exposure to H<sub>2</sub>S leading to corrosion in metallic and concrete elements, shortening their lifespan.

As will be discussed later, there is an equalization tank currently being constructed directly adjacent to the primary clarifiers and the aeration basins. This equalization tank reduces the available space for secondary treatment expansion. However, if the primary clarifiers are rebuilt to the north of the site and the existing ones are demolished, the space can be used for aeration basin expansion for secondary treatment. Therefore, we have included three new primary clarifiers



(along with a new headworks building) in the base case expansion scenario. With proper grit removal installed, we have also assumed the primary sludge can be pumped directly to the sludge storage tank as opposed to the gravity thickeners.

## AERATION BASINS – ACTIVATED SLUDGE PROCESS

The wastewater flows out of the primary clarifiers and into a common channel for conveyance to the three aeration basins. The original construction installed two aeration basins, with a third added in 2008. The 2016 ISL report noted a plug flow conventional activated sludge (CAS) treatment system.

The first two aeration basins installed are 1,460 m<sup>3</sup> and the third aeration basin installed as part of a 2008 expansion is 1,539 m<sup>3</sup> (ISL 2016). The aeration basins are fit with fine bubble diffusers that are supplied from five (four duty/one standby) centrifugal blowers designed for 55 m<sup>3</sup>/min at 48 kPa (ISL 2016). The blowers are located in the process building adjacent to the aeration tanks and primary clarifiers. Four blowers were installed in the 1982 construction with a fifth blower added during the 2008 expansion (ISL 2016).

The capacity of the aeration basins was reviewed based on the updated flow and load information to determine organic and hydraulic loading rates to the process, and these were compared with textbook recommended design values. The plug flow regime described in ISL 2016 is an important characteristic of the system as it effects the recommended organic loading rates that are used for design and operation of these processes. For the purposes of the activated sludge aeration basin capacity review we have assumed the maximum month BOD<sub>5</sub> loading to secondary treatment is applicable. We have also assumed that under maximum month conditions, there would be 35% BOD<sub>5</sub> removal in the primary clarifiers and 55% TSS removal. We note that further composite sampling testing would confirm this loading and the peaking factors used.

The capacity review for the conventional activated sludge system is summarized in Table 9. Table 9 shows the capacity review with all units receiving 100% of the load (column A), two out of three units receiving 100% of the load (column B), and two out of three units receiving 75% of the load (column C). The MWR redundancy requirement for aeration basins is that the treatment capacity shall be designed for 75% of the design flow (load) with the largest unit out of service.

*Table 9: Aeration Basin Capacity Review All Tanks in Service Receiving 100% of Load*

| DESCRIPTION                    | A. AERATION<br>BASINS (ALL<br>TANKS IN<br>SERVICE 100%<br>OF<br>FLOW/LOAD) | B. AERATION<br>BASINS (100%<br>OF<br>FLOW/LOAD<br>ONE UNIT<br>OUT OF<br>SERVICE | C. AERATION<br>BASINS (75%<br>OF<br>FLOW/LOAD<br>ONE UNIT<br>OUT OF<br>SERVICE | RECOMMENDED<br>VALUES |
|--------------------------------|--|---|--|-----------------------|
|                                |  |   |  |                       |
| No. Units                      | 3  | 2   | 2  | -                     |
| Total Volume (m <sup>3</sup> ) | 5,998  | 4,459   | 4,459  |                       |

| DESCRIPTION  | A. AERATION<br>BASINS (ALL<br>TANKS IN<br>SERVICE 100%<br>OF<br>FLOW/LOAD) | B. AERATION<br>BASINS (100%<br>OF<br>FLOW/LOAD<br>ONE UNIT<br>OUT OF<br>SERVICE | C. AERATION<br>BASINS (75%<br>OF<br>FLOW/LOAD<br>ONE UNIT<br>OUT OF<br>SERVICE | RECOMMENDED<br>VALUES |
|--|--|---|--|-----------------------|
|  |  |   |  |                       |
| 2040 Average BOD <sub>5</sub><br>Load to Aeration<br>Basins (kg/d) <sup>1</sup>      | 2,902  | 2,902   | 2,177  | -                     |
| 2040 Max Month<br>BOD <sub>5</sub> Load to<br>Aeration Basins<br>(kg/d) <sup>2</sup> | 4,951  | 4,951   | 3,173  | -                     |
| 2040 ADF (m <sup>3</sup> /d)   | 20,758   | 20,758  | 15,569   | -                     |
| 2040 AWWF (m <sup>3</sup> /d)  | 29,233   | 29,233  | 21,925   | -                     |
| 2040 2 x ADWF  | 34,419   | 34,419  | 25,815   | -                     |
| 2040 Average Organic<br>Loading Rate<br>(kg/m <sup>3</sup> *d)                       | 0.65   | 0.99  | 0.75   | 0.3 – 0.7             |
| 2040 Max Month<br>Organic Loading Rate<br>(kg/m <sup>3</sup> *d)                     | 0.92   | 1.70  | 1.27   | 0.3 – 0.7             |
| 2040 ADF Hydraulic<br>Retention Time (hr)  | 5.2  | 3.4   | 4.5  | 4 – 8                 |
| 2040 AWWF<br>Hydraulic Retention<br>Time (hr)  | 3.7  | 2.4   | 3.2  | 4 – 8                 |
| 2040 2 x ADWF<br>Hydraulic Retention<br>Time (hr)                                    | 3.1  | 2.0   | 2.7  | 4 – 8                 |

<sup>1</sup>Assumes 40% removal of BOD<sub>5</sub> during average loading in primary clarifiers

<sup>2</sup>Assumes 35% removal of BOD<sub>5</sub> during max month loading in primary clarifier.

As can be seen in Table 9, the organic loading capacity is pushing the limits of recommended design values under the maximum month and average load condition with all units in service (column A). The max month organic loading in 2040 with the largest unit out of service is 80% higher (1.27 vs. 0.7 kg BOD<sub>5</sub>/m<sup>3</sup>\*d) than the maximum recommended value, indicating the current system will not meet the redundancy requirements in 2040 (column C). We have also included column B, which indicates what the loading to the aeration basins would be if an aeration basin ever needed to be taken offline during the max load and/or flow conditions. As can be seen in this scenario (column C), the aeration basins would be overloaded in 2040 and 2020 as well. If the basins are overloaded, as shown, this would indicate difficulty for the CVWPCC to meet effluent criteria.

The 2020 loading under max month condition with all units in service is at 0.95 kg BOD<sub>5</sub>/m<sup>3</sup>\*d, also exceeding the recommended maximum design value. This indicates the need to confirm the requirement for increased activated sludge process volume; and potential construction of additional aeration basin volume as soon as possible to be prepared for current and future loads.

It is important to note that the recommended design values, taken from the Metcalf & Eddy (2014) textbook Table 8-19, are a general guideline or “rule-of-thumb” for plug flow conventional activated sludge (CAS) systems. We have worked with other municipalities where the operating organic loading rate is higher than recommended design ranges, and these facilities still meet target effluent criteria. However, these values do provide a good indication of where the normal operating range of the plant should be for optimum performance, without detailed modelling. We also found after a brief review of the effluent samples where the concentration of BOD<sub>5</sub> exceeded the permitted value 25 times in four years in bi-weekly grab (assumed) samples. Additionally, the ISL (2016) report’s review of plant effluent data indicated several occurrences where effluent BOD<sub>5</sub> exceeded the plant’s permitted value of 45 mg/L between 2011 – 2015, indicating that the activated sludge process volume may be a concern at today’s flows and loads.

As discussed previously, the textbook recommended organic loading rates selected are for a plug flow CAS process. The existing infrastructure could potentially be modified to a step-feed CAS system or a completely mixed activated sludge system (CMAS), where the organic loading rate is more forgiving and can be increased. For example, the range on a step-feed CAS system is 0.7 – 1.0 kg BOD<sub>5</sub>/m<sup>3</sup>\*d and for a CMAS system it is 0.3 – 1.6 kg BOD<sub>5</sub>/m<sup>3</sup>\*d (Metcalf & Eddy 2014). The feasibility of modifying the existing conventional activated sludge process to increase the allowable capacity with the existing tank volume would require a more detailed assessment and analysis. Regardless, we have assumed additional aeration basin volume is required for the plant. This is consistent with the ISL (2016) report which indicated additional process volume would be required by around 2024. We have assumed a volume of approximately 2,500 m<sup>3</sup> is required, this will provide the CVWPCC with enough volume to achieve 0.7 kg BOD<sub>5</sub>/m<sup>3</sup>\*d in 2040 with all four tanks running. We have assumed the additional process volume could be achieved by making the new aeration tank the same footprint size, but with a deeper side water depth (6 meters vs. 3.6 meters).

With the construction of an equalization tank directly to the east of the aeration basins, the available space for secondary treatment expansion is limited. By demolishing the existing primary clarifiers and rebuilding them to the north of the site, flow splitting can be provided for the secondary treatment tanks and the space for the old primary clarifier tanks can be used for secondary treatment expansion. Additionally, with new primary clarifiers being constructed and a

raised hydraulic profile, flow splitting can be incorporated between the four aeration basins. We have included a new aeration basin in the base case along with a flow splitting element.

The blower capacity was also reviewed for the aeration basins to confirm capacity of the existing blowers. According to the ISL (2016) report there are 5 blowers (4 duty/1 standby) that have a rated capacity of 55 m<sup>3</sup>/min at 20 degrees Celsius and 48 kPa. The estimated 2040 blower capacity is outlined in Table 10. We have also included the estimated aeration demand for nitrification of ammonia to nitrate in the process tanks. While nitrification is not required to meet the effluent criteria, it will generally occur in aeration tanks during the summer months and provide an additional demand on the blowers.

*Table 10: Estimated Blower Capacity*

| DESCRIPTION  | BLOWER CAPACITY |
|--|-----------------|
| 2040 Max Month BOD <sub>5</sub> Load in Primary Effluent (kg/d)                  | 4,951           |
| 2040 Estimated Total Airflow for BOD Removal (m <sup>3</sup> /min) <sup>1</sup>  | 142             |
| 2040 Max Month TKN Load in Primary Effluent (kg/d)                               | 562             |
| 2040 Estimate Total Airflow for TKN oxidation (m <sup>3</sup> /min) <sup>2</sup> | 75              |
| 2040 Estimated Total Airflow (m <sup>3</sup> /min)                               | 217             |

<sup>1</sup>Estimated airflow based on AOR 4,951 kg O<sub>2</sub>/d, alpha factor of 0.6, beta of 0.95, summer temperature of 22 degrees Celsius, design dissolved oxygen concentration of 2 mg/L, and standard oxygen transfer efficiency of 20%.

<sup>2</sup>Estimated airflow based on AOR 2,585 kg O<sub>2</sub>/d, alpha factor of 0.6, beta of 0.95, summer temperature of 22 degrees Celsius, design dissolved oxygen concentration of 2 mg/L, and standard oxygen transfer efficiency of 20%.

<sup>3</sup>Assumes 35% max month TKN removal in primary clarifiers.

It is estimated that the current airflow demand for 2040 maximum month conditions can be handled by the existing blowers. The condition of the existing blowers is unknown, however the blowers from the original design are nearly 40 years old and will be nearly 60 by 2040 and seemingly near the end of their serviceable life. However, we have assumed that the existing blowers can be used until 2040 to service all four aeration basins.

## SECONDARY CLARIFIERS

Similar to the aeration basins, two secondary clarifiers were installed in the original 1982 construction with a third clarifier being added as part of the 2008 expansion. The original clarifiers are 23.17 meters in diameter and are 3.13 meters deep (ISL 2016). The third clarifier is 23.1 meters in diameter with a deeper depth of 5.0 meters (ISL 2016). It is noteworthy that an important aspect of secondary clarifier design is the tank side water depth (SWD). The SWD of

the original clarifiers (3.13 meters) is considered shallow for this size of clarifier, hence likely why the third clarifier was constructed to a deeper depth.

The liquid that is separated from the solids by gravity settling in these clarifiers is then directed to the effluent outfall. The settled solids are directed through the return activated sludge (RAS) pumping system. There are three RAS pumps (three duty), one dedicated for each clarifier, located in the basement of the mechanical building (below the blowers).

There are two (one duty/one standby) waste activated sludge (WAS) pumps that remove sludge from the RAS piping to the solids processing facilities. According to the ISL report, the WAS pumps can remove sludge from the RAS line or directly from the aeration basins (ISL 2016).

The secondary clarifier capacity was reviewed with the updated flow information to determine surface overflow rates (SOR) and solids loading rates (SLR) to the clarifier. These loading factors are compared with textbook recommended design values to gauge the capacity of the existing system and when an upgrade may be required.

The capacity assessment is shown in Table 11 for the all the clarifiers receiving 100% of the flow, two of three clarifiers receiving 100% of the flow, and two of three clarifiers receiving 75% of the 2040 flow with one unit out of service (MWR requirement).

*Table 11: Secondary Clarifier Capacity Assessment*

| DESCRIPTION                          | A.<br>SECONDARY<br>CLARIFIERS<br>ALL UNITS IN<br>SERVICE<br>100% OF<br>FLOW | B.<br>SECONDARY<br>CLARIFIERS<br>ONE UNIT<br>OUT OF<br>SERVICE<br>100% OF<br>FLOW | C.<br>SECONDARY<br>CLARIFIERS<br>ONE UNIT<br>OUT OF<br>SERVICE<br>75% OF<br>FLOW | RECOMMENDED<br>VALUES |
|--------------------------------------|---|---|--|-----------------------|
| No. Units                            | 3   | 2   | 2  | -                     |
| Total Surface Area (m <sup>2</sup> ) | 1,262   | 841   | 841  |                       |
| 2040 ADF (m <sup>3</sup> /d)         | 20,758  | 20,758  | 15,569   | -                     |
| 2040 AWWF (m <sup>3</sup> /d)        | 29,233  | 29,233  | 21,925   | -                     |
| 2040 2 x ADWF (m <sup>3</sup> /d)    | 34,419  | 34,419  | 25,815   | -                     |
| 2040 PHF (m <sup>3</sup> /d)         | 62,274  | 62,274  | 46,706   | -                     |
| 2040 RAS Flow/2040 ADF               | 1.0   | 1.0   | 1.0  | -                     |



| DESCRIPTION   | A.<br>SECONDARY<br>CLARIFIERS<br>ALL UNITS IN<br>SERVICE<br>100% OF<br>FLOW | B.<br>SECONDARY<br>CLARIFIERS<br>ONE UNIT<br>OUT OF<br>SERVICE 100%<br>OF FLOW | C.<br>SECONDARY<br>CLARIFIERS<br>ONE UNIT<br>OUT OF<br>SERVICE 75%<br>OF FLOW | RECOMMENDED<br>VALUES |
|---|---|--|---|-----------------------|
| 2040 MLSS<br>Concentration (mg/L)   | 2,500   | 2,500  | 2,500   | -                     |
| 2040 Average Surface<br>Overflow Rate<br>(m <sup>3</sup> /m <sup>2</sup> *d)  | 16  | 25   | 19  | 16 – 28               |
| 2040 AWWF Surface<br>Overflow Rate<br>(m <sup>3</sup> /m <sup>2</sup> *d)     | 23  | 35   | 26  | 16 – 28               |
| 2040 2 x ADWF<br>Surface Overflow rate<br>(m <sup>3</sup> /m <sup>2</sup> *d) | 27  | 41   | 31  | 16 – 28               |
| 2040 PHF Surface<br>Overflow Rate<br>(m <sup>3</sup> /m <sup>2</sup> *d)      | 49  | 74   | 56  | 40 – 64               |
| 2040 Average Solids<br>Loading Rate<br>(kg/m <sup>2</sup> /hr)                | 3.4   | 5.1  | 3.9   | 4 – 6                 |
| 2040 AWWF Solids<br>Loading Rate<br>(kg/m <sup>2</sup> /hr)                   | 4.1   | 6.2  | 4.6   | 4 – 6                 |
| 2040 2 x ADWF Solids<br>Loading Rate<br>(kg/m <sup>2</sup> /hr)               | 4.6   | 6.8  | 5.1   | 4 – 6                 |
| 2040 PHF Solids<br>Loading Rate<br>(kg/m <sup>2</sup> /hr)                    | 6.9   | 10.3   | 7.7   | 8                     |

The capacity assessment shown in Table 11 seems to indicate there is sufficient secondary clarifier capacity to reach 2040 and still meet the MWR redundancy requirements (column C). However, at higher sustained flows with a clarifier out of service (column B), there is risk that the clarifier performance will be limited and cause effluent criteria to be exceeded for TSS and BOD<sub>5</sub>. In general, the solids loading rate criteria governs with clarifier design, and it can be seen in the above tables that the solids loading for the clarifiers are near the high-end values as recommended by Metcalf & Eddy (2014) with one unit out of service. This indicates that additional secondary clarifier capacity is required.

Additionally, the ISL (2016) report noted that the sludge settleability at the CVWPCC can be problematic. For example, the average sludge volume index (SVI) – a measure of sludge settleability – was 261 mL/g in 2015. For reference, 150 mL/g is considered average and 100 mL/g or less is considered good settling sludge. The CVWPCC poor settling sludge, at least in 2015, may suggest a need to modify the maximum allowable solids loading and surface overflow design range recommended values in the clarifiers. Additionally, in a review of the ISL (2016) report by Dr. Bill Oldham, he commented that the shallow depth of two of the secondary clarifiers may reduce their capacity by 20% to 25%, this reduction in capacity is not shown in Table 11.

Review of the effluent TSS concentration from the ISL (2016) report seem to indicate that the CVWPCC regularly meets the permissible effluent TSS concentration regulated by the MWR and the WSER. Based on data from 2011 to 2015 shown in ISL (2016), the monthly average effluent TSS concentration is below 20 mg/L, with occasional daily concentrations spiking as high as 35 mg/L, still below the permitted maximum daily effluent TSS concentration of 60 mg/L. However, a brief review of the 2013 – 2017 effluent data indicated 17 times where the concentration exceeded the permitted value of 60 mg/L based on 3 – 4 grab (assumed) samples taken per week.

Theoretically, the loading rates in 2040 are within normal operating points, although nearing the high-side during high flows. However, if poor settling sludge continues (e.g. SVI greater than 200 mL/g), a fourth clarifier would be required. Additionally, the 20 – 25% capacity reduction by Dr. Oldham has not been factored into Table 11. Lack of a controlled flow splitting system may cause issues with the clarifiers as well. The assessment in Table 11 assumes an equal flow split.

Considering the possible less than adequate performance of the shallower clarifiers, we have included a fourth secondary clarifier of equal diameter (23.1 m) and depth (5.0 m) as clarifier #3, in the base case scenario for the 2040 design flows. This is consistent with the recommendations for the ISL 2016 report and the review completed by Dr. Oldham, where he recommended constructing a new secondary clarifier as soon as possible. We have assumed that the RAS pumps would be installed in the basement of the new headworks building.

## GRAVITY THICKENERS

The circular gravity thickeners were originally constructed in 1982 to thicken combined primary sludge (PS) and WAS; however, when the dissolved air flotation (DAF) units were added this practice was abandoned. Currently, the gravity thickeners, which operate similarly to secondary clarifiers, only thicken PS that comes from the primary clarifier grit classifiers. There are two thickeners each with a diameter of 7.32 meters and depth of 3.05 meters.

The supernatant from the thickeners is returned to the liquid process and the thickened primary sludge (TPS) is directed to a thickened sludge storage tank where it is combined with the DAF thickened waste activated sludge (TWAS).

Like secondary clarifiers, thickeners are assessed on their surface overflow rate and solids loading rates. These rates, along with textbook recommended design values, are summarized in Table 12 to assess the capacity of the thickeners. There are no MWR redundancy requirements for gravity thickeners. The overflow rate is based on the primary sludge pumping capacity, which is reported as 33 L/s in ISL (2016).

*Table 12: Gravity Thickeners Capacity Assessment*

| DESCRIPTION   | GRAVITY THICKENERS (BOTH UNITS ONLINE) | GRAVITY THICKENERS (ONLY ONE UNIT ONLINE) | RECOMMENDED VALUES |
|---|--|---|--------------------|
| No. Units   | 2                                      | 1   | -                  |
| Total Surface Area (m <sup>2</sup> )                      | 84.2                                   | 42.1                                      | -                  |
| 2040 Average PS to Thickener (kg/d) <sup>1</sup>          | 3,929                                  | 3,929                                     | -                  |
| 2040 Max Month PS to Thickener (kg/d) <sup>2</sup>        | 4,522                                  | 4,522                                     | -                  |
| PS Flow Rate (m <sup>3</sup> /d (L/s))                    | 2,850 (33)                             | 2,850 (33)                                | -                  |
| Average Solids Loading Rate (kg/m <sup>2</sup> *d)        | 47                                     | 93  | 100 – 150          |
| Max Month Solids Loading Rate (kg/m <sup>2</sup> *d)      | 54                                     | 107                                       | 100 – 150          |
| Surface Overflow Rate (m <sup>3</sup> /m <sup>2</sup> *d) | 34                                     | 68  | 14.5 – 31          |

<sup>1</sup>Based on 65% TSS removal in Primary Clarifiers

<sup>2</sup>Based on 55% TSS removal in Primary Clarifiers

As can be in Table 12, the gravity thickeners are hydraulically overloaded due to a thin primary sludge. According to ISL (2016) the primary sludge concentration is less than 0.1%, which is the reason for the low solids loading but the high surface overflow rate. However, ISL (2016) reported that operations staff do not have any issues with the gravity thickeners and they perform well under the current loading conditions. The thin primary sludge is required for the grit classifier

equipment to work that the primary sludge is pumped to before the gravity thickeners. The very thin primary sludge is abnormal, typically primary sludge concentration should be 3% to 5% total solids. If proper grit removal equipment is installed that removes the entirety of the grit, then the primary clarifiers can be operated normally with a thicker primary sludge concentration pumped from the clarifiers. In this scenario, it would be expected that the gravity thickeners could be decommissioned, as the primary clarifiers would adequately thicken the sludge themselves; the primary sludge could be pumped directly to the thickened sludge storage tank where it is combined with the WAS.

## DISSOLVED AIR FLOTATION

The dissolved air flotation (DAF) units were installed during the 2000's and the practice of co-thickening WAS and PS in the gravity thickeners was abandoned. The WAS from the secondary clarifiers is pumped to two DAF units through the WAS pumps. The DAF units are 9 meters long by 2.44 meters wide and 2.1 meters deep. Under normal operation, there is a single DAF unit operating and one-unit acts as a standby unit (ISL 2016). The average capacity of each DAF unit is 46 m<sup>3</sup>/hr (ISL 2016). It is assumed that the WAS is dosed with a polymer system prior to entering the DAF to assist with flocculating and thickening the sludge, however information regarding the polymer system was not available at the time of this memorandum.

After the DAF, the TWAS is conveyed by gravity to a TWAS holding tank. From this tank it is pumped to the thickened primary sludge (TPS) holding tank where it is combined. From here, the combined TWAS and TPS is sent to the centrifuges for dewatering and then eventually trucked to composting. The liquid from the DAF unit is sent back to the liquid train of the treatment plant.

The DAF units' capacity that is reported in ISL (2016) is shown in Table 13.

*Table 13: DAF Unit Process Description*

| DESCRIPTION   | DAF CAPACITY (2 UNITS ONLINE) | DAF CAPACITY (1 UNIT ONLINE) |
|---|-------------------------------|------------------------------|
| No. of Units  | 2                             | 1                            |
| Rated Capacity (m <sup>3</sup> /hr) <sup>1</sup>              | 130                           | 65                           |
| Average Capacity (m <sup>3</sup> /hr) <sup>1</sup>            | 92                            | 46                           |
| 2015 Average Daily WAS (m <sup>3</sup> /d) <sup>1</sup>       | 695                           | 695                          |
| 2015 Maximum Month Daily WAS (m <sup>3</sup> /d) <sup>1</sup> | 884                           | 884                          |
| Total Average Operating Time (hr/d) <sup>1</sup>              | 7.5                           | 15                           |
| 2040 Average Daily WAS (m <sup>3</sup> /d) <sup>2</sup>       | 1,000                         | 1,000                        |

| DESCRIPTION                                | DAF CAPACITY (2 UNITS ONLINE) | DAF CAPACITY (1 UNIT ONLINE) |
|--|-------------------------------|------------------------------|
| 2040 Total Average Operating Time – (hr/d) | 11                            | 22                           |

<sup>1</sup>From ISL (2016) Report

<sup>2</sup>Based on an assumed sludge yield of 1 g TS/g BOD<sub>5</sub> removed and secondary sludge concentration of 0.5%.

As shown in Table 13, the DAF units have ample capacity to handle anticipated sludge flows until 2040, even with just one unit in operation. However, by 2040 the DAF units will be 30+ years old and may be due for major refurbishment or replacement; this work can be part of a larger solids handling upgrade that may be required after an assessment has been completed. A condition assessment on the DAF's should be completed to review any structural and mechanical upgrades that may be required.

## CENTRIFUGES

The plant has two centrifuges rated for a capacity of 36 m<sup>3</sup>/hr that dewater the blended thickened sludge (ISL 2016). According to the ISL report, the blended sludge ranges in concentration from 3.0% to 3.5% solids, and from this the centrifuges produce a 25% cake product (ISL 2016). The thickened sludge is pumped to the centrifuges, however information regarding the pump capacity or age was not readily available. Information regarding the polymer system was also not available at the time of this memorandum. The dewatered sludge is transferred onto screw conveyors that load the sludge onto a truck for transport to the compost facility. The centrate produced from the centrifuges is sent to an onsite septage receiving tank where it is blended with septage before being pumped to the liquid treatment train.

The centrifuges capacity as reported in ISL (2016) is shown in Table 14.

*Table 14: Centrifuge Rated Capacity*

| DESCRIPTION   | CAPACITY (ONE CENTRIFUGE) | CAPACITY (TWO CENTRIFUGES) |
|---|---------------------------|----------------------------|
| No. of Units  | 1                         | 2                          |
| Rated Capacity, each (m <sup>3</sup> /hr) <sup>1</sup>  | 36                        | 36                         |
| 2015 Average TPS/TWAS (m <sup>3</sup> /d) <sup>1</sup>  | 185                       | 185                        |
| 2015 Average Operating Hours per Week (hr) <sup>1</sup> | 36                        | 18                         |
| 2040 Average TPS/TWAS (m <sup>3</sup> /d) <sup>2</sup>  | 275 (~120 TPS / 155 TWAS) | 275 (~120 TPS / 155 TWAS)  |

|  |                           |                           |
|--|---------------------------|---------------------------|
| 2040 Average Operating Hours per Week (hr)               | 54                        | 27                        |
| 2040 Max Month TPS/TWAS (m <sup>3</sup> /d) <sup>2</sup> | 405 (~140 TPS / 265 TWAS) | 405 (~140 TPS / 265 TWAS) |
| 2040 Max Month Operating Hours per Week (hr)             | 79                        | 40                        |

<sup>1</sup>From ISL (2016) Report

<sup>2</sup>Based on an total primary and secondary sludge going to centrifuges and assumed thickened sludge concentration of 3.25%.

The capacity shown in Table 14 indicates the ability of the centrifuges to handle increased sludge coming from the plant until 2040. This is a reasonable operating time for the centrifuges, especially if both run during the week. Even under maximum month loading conditions the total operating time would equal approximately 79 hours per week, or 40 hours per week for each centrifuge.

The centrifuges can generally handle the additional solids; however, a detailed condition assessment should be completed to see if any restorative work is required for the centrifuges to carry them to 2040. By 2040 the centrifuges will be 30+ years old and may require replacement or significant repairs. At this time, the performance and capacity should be reviewed, to advise on potential upgrade options.

Additionally, the thickened sludge is pumped from 2 x 330 m<sup>3</sup> sludge holding tanks. According to the ISL (2016) report the sludge is blended in one tank and then stored in the second tank for the centrifuges feed pumps to pump from. The single 330 m<sup>3</sup> tank provides almost two days of storage based on 2015 TPS/TWAS average flow numbers (185 m<sup>3</sup>/d). By 2040 this storage will be reduced to almost one day of storage, meaning the centrifuges will need to run every day to empty the storage tank. Based on the current capacity of the centrifuges, it will take approximately 10 hours to empty the storage tank.

If blending is still desired in a separate tank, then a third storage tank may be required for 2040 to provide flexibility to the CVWPCC solids handling system. We have included an additional sludge storage tank as part of the base case.

## CVWPCC BASE CASE UPGRADE SUMMARY

Based on the capacity review of the CVWPCC we have assumed the following upgrade will be required to meet 2040 flow and load demands. This base case will be carried forward to the Stage 2 Wastewater Treatment Level Assessment, which will detail a cost estimate and provide site plans for the upgrades. The assumed base case upgrade will include:

- A new headworks building to the north of the administration building that provides space for screening, grit removal, primary sludge pumping, and RAS pumping. The upgrade will also include primary clarifier flow splitting and raise the overall hydraulic grade line of the wastewater treatment plant.
- Three new primary clarifiers will be constructed adjacent to the headworks building. The existing primary clarifiers and grit tanks will be demolished. The primary clarifiers will also include flow splitting elements to evenly split the flow to the aeration basins.



- A new aeration basin will be constructed where the existing primary clarifiers are currently located and will be supplied with air from the existing blowers.
- A new secondary clarifier and secondary clarifier splitter box will be installed.
- UV disinfection will be included in the expansion.

With the above upgrades the CVWPCC will have the ability to meet 2040 flow and load demands. The Stage 2 Wastewater Treatment Assessment will investigate the cost implications of additional treatment processes beyond the base case described above. Additionally, this upgrade does not include upgrades to the outfall that may be required.